CITY OF SAINT PAUL OFFICE OF THE CITY COUNCIL 310 CITY HALL 15 WEST KELLOGG BOULEVARD SAINT PAUL, MN 55102-1615 EMAIL: legislativehearings@ci.stpaul.mn.us PHONE: (651) 266-8560 FAX: (651) 266-8574

May 19, 2011

Ken Driver 5614 Twin Lake Terrace N Crystal MN 55429

Re: Appeal for property at <u>834 Selby Avenue</u>

Dear Mr. Driver:

This is to confirm that Marcia Moermond, Legislative Hearing Officer, has reviewed the abovereferenced matter and recommended granting a 6-inch variance on the openable height of the egress window in the south bedroom and a 3.5-inch variance on the openable height of the egress window in the north bedroom.

Please note that this matter will be on the City Council Legislative Hearing Consent Agenda on Wednesday, June 1, 2011 at 5:30 p.m. in Room 300 Council Chambers. It is not necessary for you to attend.

If you have any questions, you may contact me at 651-266-8563.

Sincerely,

Mai Vang Legal Hearing Coordinator

cc: Fire Supervisors (email) Pat Fish (email) File

