

CITY OF SAINT PAUL

OFFICE OF THE CITY COUNCIL 310 CITY HALL 15 WEST KELLOGG BOULEVARD SAINT PAUL, MN 55102-1615

EMAIL: legislativehearings@ci.stpaul.mn.us
PHONE: (651) 266-8560 FAX: (651) 266-8574

June 10, 2011

Daniel Schmidt Public Health 2785 White Bear Ave N, Ste. 350 Maplewood MN 55109

VIA EMAIL: daniel.schmidt@co.ramsey.mn.us

Re: Appeal for property at 1147 Matilda Avenue

File ID: RLH WP 11-24

Dear Mr. Schmidt:

This is to confirm that Marcia Moermond, Legislative Hearing Officer, recommended granting a 2-inch variance on the openable height of three double hung replacement egress bedroom windows measuring 22 inches high by 25 inches wide.

Please note that this matter is going before the Council on Wednesday, July 6, 2011 at 5:30 p.m. in Room 300 Council Chambers. You may attend the hearing but it is not necessary since the appeal was granted.

If you have further questions, please contact me at 651-266-8563.

Sincerely,

/s/

Mai Vang Legislative Hearing Coordinator

c: Fire Supervisors (email)
Pat Fish (email)
Jim Bloom (email)
Stephen Ubl (email)