

CITY OF SAINT PAUL OFFICE OF THE CITY COUNCIL 310 CITY HALL 15 WEST KELLOGG BOULEVARD SAINT PAUL, MN 55102-1615 EMAIL: legislativehearings@ci.stpaul.mn.us PHONE: (651) 266-8560 FAX: (651) 266-8574

June 22, 2011

Bryan Horton Renewal by Andersen Corporation obo Annette & Kirby Hansen 1920 County Rd C W Roseville MN 55113

VIA EMAIL: bryan.horton@andersencorp.com

Re: Appeal for property at <u>2221 Edgcumbe Road</u> File ID: RLH WP 11-26

Dear Mr. Horton:

This is to confirm that on June 14, 2011, Marcia Moermond, Legislative Hearing Officer reviewed the above-referenced appeal and recommended that the Council grant a 3-inch variance on the openable width of three casement replacement egress bedroom windows measuring 17 inches wide by 34 ¼ inches high.

Please note that this matter will be on the Agenda for City Council on Wednesday, July 6, 2011 at 5:30 p.m. in Room 300 Council Chambers.

If you have further questions, please contact me at 651-266-8563.

Sincerely,

/s/

Mai Vang Legislative Hearing Coordinator

c: Fire Supervisors (email) Jim Bloom (email) Ryan Rehn (email) Stephen Ubl (email) File

