

APPLICATION FOR APPEAL

RECEIVED

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

1854	JUN 2 0 2011 CITY CLERK	Tolophone: (651) 266	
The City Clerk needs the following to pr	rocess vour appeal:		
\$25 filing fee payable to the City of (if cash: receipt number) Copy of the City-issued orders or le are being appealed Attachments you may wish to include This appeal form completed Walk-In OR Mail-In	Saint Paul tter which	YOUR HEARING Date and Time: Tuesday, JOY 12, 201 Time 1.30 0.00. Location of Hearing:	(
		Room 330 City Hall/Courthouse	
Address Being Appeal			
Number & Street: 885 Ma	rion City: St	+ Paul State: MN Zip: 55	47.
Appellant/Applicant: Kathleen M Non - Th Phone Numbers: Business 266-2760 Signature: Kathleen M. Hen Name of Owner (if other than Appellant): Address (if not Appellant's): 15041	nursday 657 Residence 488- Druger	-1/26 Cell <u>—</u> Date: <u>Jueno</u> 20, 201	Jely mine where is not some is the most society that is a presentation of the society of the soc
Phone Numbers: Business	Residence	Cell	+0
Revocation of Fire C of O Summary/Vehicle Abatement Fire C of O Deficiency List Fire C of O: Only Egress Windows Code Enforcement Correction Notice Vacant Building Registration Other Other Other Other Are on only Are of the	Premises occupied Son is in his 20s, oc MSFC 1003.3. on interior door. Locks are on to ensure privacy these rooms. SPLC 34.09/2) replace guardrail My son has in acode school. The	on rooms	the different it this was rental



CITY OF SAINT PAUL Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220 Saint Paul, Minnesota 55101-1806 Telephone: 651-266-8989 Facsimile: 651-266-8951 Web: www.stpaul.gov/dsi

received 6/17/2011

June 16, 2011

KATHLEEN M HENDERSON 1504 ST ALBANS ST N ST PAUL MN 55117-3426

FIRE INSPECTION CORRECTION NOTICE

RE: 885 MARION ST

Dear Property Representative:

Your building was inspected on May 16, 2011 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date.

A re-scheduled inspection will be made on July 19, 2011 at 11 AM.

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional reinspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

DEFICIENCY LIST

- 1. Exterior SPLC 34.09 (1) b,c, 34.32 (1) b,c Provide and maintain all exterior walls free from holes and deterioration. All wood exterior unprotected surfaces must be painted or protected from the elements and maintained in a professional manner free from chipped or peeling paint.-Paint all peeling areas on the trim of windows and patio/deck.
- 2. Exterior-Throughout SPLC 34.09 (2), 34.32(2) Repair or replace the damaged guardrail in an approved manner. This work requires a permit(s). Call DSI at (651) 266-9090.
- 3. Exterior-Throughout SPLC 34.09 (2), 34.32(2) Repair or replace the damaged handrail in an approved manner. This work requires a permit(s). Call DSI at (651) 266-9090.

- 4. Interior-Basement UMC 504.6 Provide, repair or replace the dryer exhaust duct. Exhaust ducts for domestic clothes dryers shall be constructed of metal and shall have a smooth interior finish. The exhaust duct shall be a minimum nominal size of four inches (102 mm) in diameter. This work require a permit(s). Call DSI at (651) 266-8989.
- 5. Interior-Basement SPLC 34.10 (7), 34.33 (6) Repair and maintain the walls in an approved manner.-Patch and paint the holes and/or cracks in the walls in the basement that appear to have a mold/mildew substance growing on them or remove the damaged sheetrock.
- 6. Interior-Basement SPLC 34.10 (1) Abate and maintain the basement reasonably free from dampness and free of mold and mildew.
- 7. Interior-Throughout MSFC 1003.3.1.8 Remove unapproved locks from the unit doors. The door must be openable from the inside without the use of keys or special knowledge or effort.
- 8. Interior-Throughout MN Stat 299F.18 Immediately remove and discontinue excessive accumulation of combustible materials.-Remove combustible materials by 50%. The home is cluttered with newspapers, and storage.
- 9. SPLC 34.11 (6), 34.34 (3) Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.

For an explanation or information on some of the violations contained in this report, please visit our web page at: http://www.ci.stpaul.mn.us/index.aspx?NID=211

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: lisa.martin@ci.stpaul.mn.us or call me at 651-266-8988 between 6:30 a.m. - 8:30 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Lisa Martin
Fire Inspector