



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-9124
Web: www.stpaul.gov/dsi

Code Compliance Report

July 21, 2011

Quality Residences LLC
923 Payne Ave
St Paul MN 55130-4001

Re: 353 Sherburne Ave
File#: 10 906988 VB3

Dear Property Owner:

The following is the Code Compliance report you requested on July 01, 2011.

Please be advised that this report is accurate and correct as of the date July 21, 2011. All deficiencies identified by the City after this date must also be corrected and all codes and ordinances must be complied with. This report is valid for 365 days from July 21, 2011. This report may be used in lieu of a Truth in Housing Report required in St Paul Legislative Code 189. This building must be properly secured and the property maintained at all times.

In order to sell or reoccupy this property the following deficiencies must be corrected:

BUILDING **Inspector: Jim Seeger** **Phone: 651-266-9046**

- Insure basement cellar floor is even, is cleanable, and all holes are filled.
- Install plinth blocks as needed under posts in basement & ensure adequate footing for load imposed.
- Tuck Point interior/exterior of foundation as necessary.
- Dry out basement and eliminate source of moisture.
- Remove mold, mildew and moldy or water damaged materials.
- Permanently secure top and bottom of support posts in an approved manner.
- Provide adequate access, ventilation and clearance in crawl space area.
- Install handrails (34 inches - 38 inches above each nosing) and guardrails (36 inch minimum) at all stairways, and return hand rail ends into a newel post or wall per attachment.
- Repair or Replace any deteriorated window sash, broken glass, sash holders, re-putty, etc as necessary.
- Provide complete storms and screens, in good repair for all door and window openings.
- Provide functional hardware at all doors and windows
- Repair or replace damaged doors and frames as necessary, including storm doors.
- Weather seal exterior doors, threshold and weather-stripping.

Re: 353 Sherburne Ave
July 21, 2011
Page 2

BUILDING **Inspector: Jim Seeger** **Phone: 651-266-9046**

- Install floor covering in bathroom and kitchen that is impervious to water.
- Repair walls, ceiling and floors throughout, as necessary.
- Prepare and paint interior and exterior as necessary. Observe necessary abatement procedures (EPA, MPCA and St. Paul Legislative Code, Chapter 34 for additional information) if lead base paint is present.
- Provide fire block construction as necessary and seal chases in basement ceiling.
- Where wall and ceiling covering is removed install full thickness or code-specified insulation.
- Air-seal and insulate attic/access door.
- Install Smoke Detectors/Carbon Monoxide Detectors per MN Co Conservation Code and the MN Dept. of Labor and Industry.
- Provide major clean-up of premises.
- Repair siding, soffit, fascia, trim, etc. as necessary.
- Provide proper drainage around house to direct water away from foundation of house.
- Provide proper drainage around house to direct water away from foundation of garage.
- Install downspouts and a complete gutter system.
- Install rain leaders to direct drainage away from foundation.
- Replace house and garage roof covering and vents to code.
- Provide general rehabilitation of garage.
- Review all applicable codes & policies when replacing windows including egress windows for sleeping rooms.
- Remove trees which are against foundation of home and garage.
- Replace front steps at street.
- Install 1 hour fire rated wall assembly at west and north side of garage.
- Remove all stucco and reside house, replace all decayed framing and sheathing.
- Totally replace or rebuild front porch area of house.
- Remove all wall, floor and ceiling covering from house and repair to code with inspections.
- Roof covering appears to have been leaking into house - replace to code.
- A building permit is required to correct the above deficiencies.

ELECTRICAL **Inspector: Dan Jambor** **Phone: 651-266-9032**

- Ground the electrical service to the water service with a copper conductor within 5 feet of the entrance point of the water service
- Bond around water meter with a copper wire sized for the electrical service per Article 250 of the NEC
- Provide a complete circuit directory at service panel indicating location and use of all circuits
- Verify/install a separate 20 ampere laundry circuit and a separate 20 ampere kitchen appliance circuit
- Verify that fuse/circuit breaker amperage matches wire size
- Remove all cord wiring

Re: 353 Sherburne Ave
July 21, 2011
Page 3

ELECTRICAL **Inspector: Dan Jambor** **Phone: 651-266-9032**

- Close openings in service panel/junction box with knock out seals, breaker blanks and/or junction boxes
- Properly strap cables and conduits in basement/ service conduit on the exterior of the house.
- Install/replace GFCI receptacle in basement/first/second bathroom adjacent to the sink
- Ground bathroom light in basement/first bathroom/second bathroom and disconnect receptacle on fixture
- Install globe-type enclosed light fixture on all closet lights
- Repair or Replace all broken, missing or loose light fixtures, switches and outlets, covers and plates
- Check all outlets for proper polarity and verify ground on 3-prong outlets
- Remove any 3-wire ungrounded outlets and replace with 2-wire or ground 3-wire to code
- Remove and or/ re-wire all illegal, improper or hazardous wiring in basement/garage
- Replace all painted-over receptacles.
- Throughout building, install outlets and light fixtures as specified in Bulletin 80-1.
- All added receptacles must be grounded, tamper-resistant and be on an Arc-Fault Circuit Interrupter-protected circuit.
- Any open walls or walls that are opened as part of this project must be wired to the standards of the current NEC.
- All buildings on the property must meet the St. Paul Property Maintenance Code (Bulletin 80-1).
- All electrical work must be done by a Minnesota-licensed electrical contractor under an electrical permit.

PLUMBING **Inspector: Tom Schweitzer** **Phone: 651-266-9055**

- Basement - Water Heater - No gas shut off or gas piping incorrect (IFGC 402.1)
- Basement - Water Heater - not fired or in service (MPC 2180)
- Basement - Water Meter - meter is removed or not in service (MPC 4715.1700)
- Basement - Water Meter - raise meter to a minimum 12 inches above floor (MPC 2280)
- Basement - Water Piping - run 1 inch water line from meter to first major take off (SPRWS Water Code)
- Basement - Soil and Waste Piping - improper connections, transitions, fittings or pipe usage (MPC 2420)
- Basement - Soil and Waste Piping - no soil stack base clean out
- Basement - Soil and Waste Piping - replace corroded cast iron or steel waste piping (MPC 0200)
- First Floor - Sink - unvented (MPC 0200. E)
- First Floor - Sink - waste incorrect (MPC 2300)
- Second Floor - Lavatory - unvented (MPC 0200. E)
- Second Floor - Tub and Shower - Provide access (MPC 0900)
- Second Floor - Tub and Shower - provide anti-scald valve (MPC 1380. Subp. 5)
- Second Floor - Tub and Shower - provide stopper (MPC 1240)

Re: 353 Sherburne Ave
July 21, 2011
Page 4

PLUMBING **Inspector: Tom Schweitzer** **Phone: 651-266-9055**

- Second Floor - Tub and Shower - water piping incorrect (MPC 0200 P.)
- Exterior - Lawn Hydrants - Requires backflow assembly or device (MPC 2000)
- Obtain plumbing permits prior to commencement of work.

HEATING **Inspector: Kevin Chapdelaine** **Phone: 651-266-9042**

- Install approved lever handle manual building shutoff gas valve in an accessible location ahead of the first branch tee.
- Clean and Orsat test boiler burner. Check all controls for proper operation. Provide documentation from a licensed contractor that the heating unit is safe.
- Vent clothes dryer to code.
- Provide adequate combustion air and support duct to code.
- Provide appropriate size operable window in bathrooms or provide exhaust system vented to outside. A mechanical ventilation permit is required if an exhaust system is installed.
- Install back flow preventer on city water fill line to hot water heating system and pipe vent as required.
- Repair or replace fin tube radiation and covers as needed.
- Install expansion tank according to manufacturer's installation instructions.
- Gas and hydronic mechanical permits are required for the above work.

ZONING

1. This property is in a (n) RT1 zoning district.
2. This property was inspected as a Single Family Dwelling.

Notes:

- See attachment for permit requirements and appeals procedure.
- This property is designed by the Vacant Buildings Department as a Category #3 which requires a \$5000.00 Performance Bond or Deposit at the time the permit is issued.
- Interior of garage not available for inspection. Repair per applicable codes.

This is a registered vacant building. In order to sell or reoccupy this building, all deficiencies listed on this code compliance report must be corrected in accordance with the Minimum Housing Standards of the St. Paul Legislative Code (Chapter 34) and all required permits must receive final approval within six (6) months of the date of this report. One (1) six-month time extension may be requested by the owner and will be considered if it can be shown that the code compliance work is proceeding and is more than fifty (50) percent complete in accordance with Legislative Code Section 33.03(f).

Re: 353 Sherburne Ave
July 21, 2011
Page 5

You may file an appeal to this notice by contacting the City Clerk's Office at 651-266-8688. Any appeal must be made in writing within 10 days of this notice. (You must submit a copy of this notice when you appeal, and pay a filing fee.)

If you have any questions regarding this inspection report, please contact Jim Seeger between 7:30 - 9:00 AM at 651-266-9046 or leave a voice mail message.

Sincerely,

James L. Seeger
Code Compliance Officer
Department of Safety and Inspections
City of Saint Paul
375 Jackson Street, Suite 220
Saint Paul MN 55101
Phone: 651-266-9046
Email: james.seeger@ci.stpaul.mn.us

JLS:ml
Attachments