

□ Code Enforcement Correction Notice

Vacant Building Registration

□ Other

APPLICATION FOR APPEAL

Saint Paul City Clerk

RECEIVED
JUL 27 2011

310 City Hall, 15 W. Kellogg Blvd. Saint Paul, Minnesota 55102 Telephone: (651) 266-8560

**Substitute of the City of Saint Paul (if cash: receipt number () Copy of the City-issued orders or letter which are being appealed Attachments you may wish to include This appeal form completed Walk-In OR Mail-In	YOUR HEARING Date and Time: Tuesday, 8-2-11 Time //:00 a m: Location of Hearing: Room 330 City Hall/Courthouse
Address Being Appealed:	
Number & Street: 295 Stinson City: St. Paul State: Mn Zip: 55117	
Appellant/Applicant: Brenda Wright	Email
Phone Numbers: Business Residence	Cell 651-399-6248
Signature: Brenole Wright	Date: 27/27/1/
Name of Owner (if other than Appellant):	
Address (if not Appellant's):	
Phone Numbers: Business Residence	Cell
What Is Being Appealed and Why? Attachments Are Acceptable	
Vacate Order/Condemnation/ Revocation of Fire C of O	
□ Summary/Vehicle Abatement	
□ Fire C of O Deficiency List	
☐ Fire C of O: Only Egress Windows	



CITY OF SAINT PAUL Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220 Saint Paul, Minnesota 55101-1806

 Telephone:
 651-266-8989

 Facsimile:
 651-266-8951

 Web:
 www.stpaul.gov/dsi

July 25, 2011

JONATHAN & ELIZABETH BRUNTJEN TWIN CITIES REAL ESTATE PARTNERS LLC 440 OLD LONG LAKE RD. SUITE A WAYZATA MN 55391-9631

NOTICE OF CONDEMNATION UNFIT FOR HUMAN HABITATION ORDER TO VACATE

RE: 295 STINSON ST

Dear Property Representative:

Your building was inspected on July 25, 2011.

The building was found to be unsafe, unfit for human habitation, a public nuisance, a hazard to the public welfare or otherwise dangerous to human life. A Condemnation Placard has been posted on the building.

The following deficiency list must be completed or the building vacated by the re-inspection date.

CONDEMNATION OF THE BUILDING REVOKES THE CERTIFICATE OF OCCUPANCY.

Failure to complete the corrections may result in a criminal citation. The Saint Paul Legislative Code requires that no building be occupied without a Fire Certificate of Occupancy.

DEFICIENCY LIST

- 1. Exterior SPLC 34.09 (1) b,c, 34.32 (1) b,c Provide and maintain all exterior walls free from holes and deterioration. All wood exterior unprotected surfaces must be painted or protected from the elements and maintained in a professional manner free from chipped or peeling paint.-Repair the siding blowing off the house.
- 2. Exterior SPLC 34.08 (10) Repair, replace and maintain exterior sidewalks, walkways and stairs.

- 3. Exterior SPLC 34.08 (7) All parking spaces shall be paved with asphalt, concrete, or durable dustless surfacing. Before any existing spaces may be paved, site plan approval must be obtained as specified in the St. Paul Zoning Code. Contact DSI Zoning at 651-266-9090.
- 4. Exterior SPLC 163.03, 163.01 (2), (3) Currently license (tabs) all vehicles on the property and return the vehicles to an operative mechanical condition or remove vehicles from the property.
- 5. Exterior SPLC 34.09 (2), 34.32(2) Repair or replace the unsafe stairways, porch, decks or railings in an approved manner. This work may require a permit(s). Call DSI at (651) 266-9090.
- 6. Interior SPLC 34.10 (7), 34.33 (6) Repair and maintain the ceiling in an approved manner.-Pull permits to repair damaged sheetrock and repair all leaks damaging the ceilings and walls throughout.
- 7. Interior SPLC 34.11 (6), 34.34 (3) Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.
- 8. Interior SPLC 34.19 Provide access to the inspector to all areas of the building.
- 9. Interior UMC 504.6 Provide, repair or replace the dryer exhaust duct. Exhaust ducts for domestic clothes dryers shall be constructed of metal and shall have a smooth interior finish. The exhaust duct shall be a minimum nominal size of four inches (102 mm) in diameter. This work may require a permit(s). Call DSI at (651) 266-8989.-Repair the damaged dryer vent to meet code. Permit required.
- 10. Interior SPLC 34.10 (7), 34.33 (6) Repair and maintain the walls in an approved manner.-Repair or replace the damaged or deteriorated open face insulation to meet code in the basement.
- 11. Interior SPLC 34.11 (5), 34.34 (2) Contact a licensed contractor to repair or replace the water heater. This work may require a permit(s). Call DSI at (651) 266-9090.
- 12. Interior SPLC 34.23, MSFC 110.1 This occupancy is condemned as unfit for human habitation. This occupancy must not be used until re-inspected and approved by this office.-Condemned due to over-occupancy, water damage throughout causing electrical issues, and general lack of maintenance.
- 13. Interior SPLC 34.19 Provide access to the inspector to all areas of the building.
- 14. Interior-Throughout MSFC 605.1- All light fixtures shall be maintained with protective globes if originally equipped.

- 15. Interior-Unit 1 SPLC 34.14 (2), 34.34 (5) Provide an approved electrical service adequate to meet the buildings needs. This work may require a permit(s), call DSI at (651) 266-9090.-Hire a licensed electrician to repair the hard wire smoke detector, light fixtures and outlets that are not working.
- 16. Interior-Unit 2 SPLC 34.13 (3), SPLC 34.17 (2) Reduce and maintain the number of occupants in the sleeping rooms.
- 17. Interior-Unit 2 SPLC 34.13 (2), (3), SPLC 34.17 (2) Reduce and maintain the number of occupants in the unit.

For an explanation or information on some of the violations contained in this report, please visit our web page at: http://www.ci.stpaul.mn.us/index.aspx?NID=211

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of the original orders.

If you have any questions, email me at: lisa.martin@ci.stpaul.mn.us or call me at 651-266-8988 between 6:30 - 8:30 a.m. Please help make Saint Paul a safer place in which to live and work.

Sincerely,

Lisa Martin Fire Inspector

cc: Housing Resource Center
Force Unit