



APPLICATION FOR APPEAL

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

RECEIVED

AUG 26 2011

The City Clerk needs the following to process your appeal: **CITY CLERK**

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed
- Walk-In OR Mail-In

YOUR HEARING Date and Time:

Tuesday, Sept 13, 2011

Time 1:30 p.m.

Location of Hearing:
Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 387 Grand City: St. Paul State: MN Zip: 55102

Appellant/Applicant: Carlton E Morris Email: carltoncj@aol.com

Phone Numbers: Business _____ Residence _____ Cell 651 592 7340

Signature: [Signature] Date: 8/26/11

Name of Owner (if other than Appellant): _____

Address (if not Appellant's): _____

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being Appealed and Why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other

It is my opinion that some of the deficiencies were not necessary and somewhat punitive.



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

August 19, 2011

CARLTON E MORRIS/ELAINE MORRIS
387 GRAND AVE APT 2
SAINT PAUL MN 55102

FIRE INSPECTION CORRECTION NOTICE

RE: 387 GRAND AVE
Residential Class: C

Dear Property Representative:

Your building was inspected on August 12, 2011 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date.

A re-inspection will be made on September 20, 2011 at 1:00 PM.

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

DEFICIENCY LIST

1. 1st Floor - Bathroom - SPLC 34.10 (7), 34.33 (6) - Repair and maintain the ceiling in an approved manner.-Repair or replace the damaged or deteriorated ceiling.
2. 1st Floor - Bathroom - SPLC 34.10 (7), 34.33 (6) - Repair and maintain the walls in an approved manner.
-Repair or replace the damaged or deteriorated wall coverings.
-Also repair damaged and loose tiles and caulking.
3. 1st Floor - Bathroom - MSFC 605.1 - Repair or replace damaged electrical fixtures. This work may require a permit(s). Call DSI at (651) 266-9090. -Repair non-working GFI outlet.

4. 1st Floor - Bathroom - SPLC 34.09 (3), 34.32 (3) - Repair and maintain the door latch.
5. 1st Floor - Kitchen - MSFC 605.1 - Repair or replace damaged electrical fixtures. This work may require a permit(s). Call DSI at (651) 266-9090. -Repair non-working outlet.
6. 1st Floor - MSFC 605.5 - Discontinue use of extension cords used in lieu of permanent wiring.
7. 1st Floor - MSFC 605.6 - Provide electrical cover plates to all outlets, switches and junction boxes where missing.
8. 1st Floor - MN State Statute 299F.50 Immediately provide and maintain an approved Carbon Monoxide Alarm in a location within ten (10) feet of each sleeping area. Installation shall be in accordance with manufacturers instructions.
9. 3rd Floor Unit - Bathroom - SPLC 34.10 (7), 34.33 (6) - Repair and maintain the walls in an approved manner.-Repair or replace the damaged or deteriorated wall coverings.
- Repair damaged tile.
10. 3rd Floor Unit - Furnace Room - MSFC 605.6 - Provide electrical cover plates to all outlets, switches and junction boxes where missing.
11. 3rd Floor Unit - MN State Statute 299F.50 Immediately provide and maintain an approved Carbon Monoxide Alarm in a location within ten (10) feet of each sleeping area. Installation shall be in accordance with manufacturers instructions.
12. 3rd Floor Unit - SPLC 34.10 (4), 34.33 (3) - Provide a bathroom floor impervious to water.
13. Basement - Laundry Sink - SPLC 34.11, SBC 2902.1, SPLC 34.17, MPC 415.0220 - Repair or replace and maintain the plumbing fixture to an operational condition.
-Repair leaking laundry sink faucet.
14. Basement - MSFC 703 - Provide, repair or replace the fire rated door and assembly.
-Repair and maintain the door latch.
15. Basement - SPLC 34.11 (5), 34.34 (2) - New water heater was installed without permit. This work will require a permit(s). Call DSI at (651) 266-9090.
-Obtain approval under permit for new water heater installation.
16. Basement - SPLC 34.10 (1) - Abate and maintain the basement reasonably free from dampness and free of mold and mildew.
17. Basement - SPLC 34.11, SBC 2902.1, SPLC 34.17, MPC 415.0220 - Repair or replace and maintain the plumbing fixture to an operational condition. This work may require a permit. Contact DSI at 651-266-8989.-The water meter and piping is leaking.
-Contact a licensed plumber to repair leak in an approved manner.

18. Basement - SPLC 34.11 (4), 34.34 (1), MPC 4515, MPC 326 - Connect or cap the sewer piping in accordance with the plumbing code. This work may require a permit. Contact DSI at 651-266-8989. -There is an open hole in the floor near the sewer stack that has black liquid in it. -Contact a licensed plumber to evaluate hole and repair leak. Provide documentation.

19. Exterior - SPLC 34.09 (1) b,c, 34.32 (1) b,c - Provide and maintain all exterior walls free from holes and deterioration. All wood exterior unprotected surfaces must be painted or protected from the elements and maintained in a professional manner free from chipped or peeling paint.

20. Interior - SPLC 34.12 (2), 34.35 (1) - Repair and maintain all required and supplied equipment in an operative and safe condition.-Replace old smoke detectors.

21. Interior - MSFC 907.3 - Provide an approved fire alarm system. This work will require a permit(s), call DSI at (651) 266-9090.

22. Rear Entry - MSFC 1003.3.1.8 - Remove unapproved locks from the unit doors. The door must be openable from the inside without the use of keys or special knowledge or effort. -Remove slide bolt lock.

23. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit an approved completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.

24. SPLC 39.02(c) - Complete and sign the smoke detector affidavit and return it to this office.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: william.beumer@ci.stpaul.mn.us or call me at 651-266-8991 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

William Beumer
Fire Inspector

Reference Number 62458