

Other

# APPLICATION FOR APPEAL

RECEIVED
SEP 0 8 2011
CITY CLERK

The City Clerk needs the following to process your appeal:

## Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd. Saint Paul, Minnesota 55102 Telephone: (651) 266-8560

YOUR HEARING Date and Time:

THE City Clerk Reeses 11 ( 1) City of C	aint Paul	
\$25 filing fee payable to the City of S  (if cash: receipt number )	allit i aui,	Tuesday, 9-20-11
	on which	1
Copy of the City-issued orders or lett	er which	Time
		Location of Hearing:
Attachments you may wish to include	E	Room 330 City Hall/Courthouse
This appeal form completed		walk-in
Address Being Appeal		
Number & Street: 108/ 5:mS	<u>Ave</u> <u>City:</u> <u>51</u>	- Paul State: <u>MN</u> Zip: <u>55106</u>
Appellant/Applicant: Tony Swan	1 <i>501</i> Em	aail <u>anthony. Swanson @ Stpha</u> .org
Phone Numbers: Business 651-298-49	907_ Residence	Cell
Signature: Thy Sul	work	Date: 9-7-11
Name of Owner (if other than Appellant):	Public Housin	g Agency of St. Paul
Address (if not Appellant's): 555 /	J. Wabasha	Suite # 400 St. Paul, MW 55102
Phone Numbers: Business	Residence	Cell
What Is Being appeale	d and why?	Attachments Are Acceptable
Vacate Order/Condemnation/	#10 Tntex;	OR-MSFC 1026.1
Account of Table -	Rango Havin	nce on openable height.
□ Summary/Vehicle Abatement	REQUEST VUITU	me on opinate notin
□ Fire C of O Deficiency List		
<b>✗</b> Fire C of O: Only Egress Windows		
☐ Code Enforcement Correction Notice		
Yr Duilling Registration		
□ Other		
□ Other		

C: K. LYKSETT B. SHERRY

DEPARTMENT OF SAFETY AND INSPECTIONS Fire Inspection Division Ricardo X. Cervantes, Director


SALVI FAUT MANN CITY OF SAINT PAUL Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220 Saint Paul, Minnesota 55101-1806 

 Telephone:
 651-266-8989

 Facsimile:
 651-266-8951

 Web:
 www.stpaul.gov/dsi



August 23, 2011

BETTY LOU AUTHIER PUBLIC HOUSING AGENCY 200 ARCH ST E ST PAUL MN 55130-4347



#### FIRE INSPECTION CORRECTION NOTICE

RE:

1081 SIMS AVE

Ref. #111436

Residential Class: B

#### Dear Property Representative:

Your building was inspected on August 22, 2011 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date.

### A re-inspection will be made on September 23, 2011 at 10:15 am.

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional reinspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

**DEFICIENCY LIST** 

K. LYKSETT- WO# 6040584

- 1. EXTERIOR SPLC 34.09 (3), 34.32 (3) Provide or repair and maintain the window screens.

  K. LYKSETT- WORF 6040585
- 2. EXTERIOR SPLC 34.09 (3), 34.32 (3) Repair and maintain the door in good condition.-Replace door closer on rear storm door.

  K. LYKSETT WOH 6040588
- 3. INTERIOR MSFC 605.1- All light fixtures shall be maintained with protective globes if originally equipped.

### K. LYKSETT - WORLOUSSE

4. INTERIOR - MSFC 1011.2 - Remove the materials that cause an exit obstruction.

Maintain a clear and unobstructed exitway.-Remove air conditioner from egress window in upstairs bedroom.

B. SHERRY— (A) WOLF 6040515 (B) WOLF 6040516

INTERIOR - SPLC 34.10 (7), 34.33 (6) - Repair and maintain the walls in an approved manner. Repair hole in wall in upstairs bedroom, patch and paint east wall in upstairs work 66

room, and repair water damaged ceiling and wall in living room. All work must be done in a professional manner.

B. SHERRY - WOH 6040587

6. INTERIOR - MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651)- 266-9090. Refer to the Escape Windows for Residential Occupanices handout for more information.-Upon inspection, double hung window in upstairs bedroom measured 19 inches openable height x 23.5 inches openable width.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: http://www.stpaul.gov/cofo

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: kelly.booker@ci.stpaul.mn.us or call me at 651-266-8985 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Kelly Booker Fire Inspector

Reference Number 111436