
Revised 8/20/2010



APPLICATION FOR APPEAL

RECEIVED
SEP 0 6 2011

CITY CLERK
The City Clerk needs the following to process your appeal:

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd. Saint Paul, Minnesota 55102 Telephone: (651) 266-8560

YOUR HEARING Date and Time:

\$25 filing fee payable to the City	of Saint Paul
(if cash: receipt number	Tuesday, 9-20-11
Copy of the City-issued orders of	Time
are being appealed	
 Attachments you may wish to in 	
This appeal form completed	Room 330 City Hall/Courthouse
·	emailed 9-6-11
Address Being Appe	ealed:
Number & Street: 2057	5th St E City: St. Paul State: MN Zip: 55119
Appellant/Applicant: Renewal b	y Andersen Email bryan, horton Pandersencorp.com
	•
Phone Numbers: Business 651-264	- 4088 Residence Cell
Signature: B	Date: 09/02/11
S. S	Date: O'ljorjii
Name of Owner (if other than Appella	unt): Nick Stark
305	
Address (if not Appellant's): 205	13-318
Phone Numbers: Business	Residence 651-735-0048 Cell
What Is Being appea	led and why? Attachments Are Acceptable
Vacate Order/Condemnation/ Revocation of Fire C of O	
· ·	We are appealing / replacement Double Hang
Summary/Vehicle Abatement	That will not comply w/ St. Paul Egress policy
□ Fire C of O Deficiency List	Openable Height will be short by 5". openable
Fire C of O: Only Egress Windows	Width Exceeded by 5" Homeowner would
Code Enforcement Correction Not	
Vacant Building Registration	the home. Please Approve.
Other	- ibutus:
Other	
1 Other	

PHONE: 651-266-8688

651-266-8574

FAX:



CITY OF SAINT PAUL INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK

15 KELLOGG BLVD. WEST

310 CITY HALL

SAINT PAUL, MN 55102

DATE: September 2, 2011

APPEAL PROPERTY ADDRESS: 2057 5TH ST E

APPLICANT NAME:

RENEWAL BY ANDERSEN CORPORATION

PHONE NUMBER:

651-264-4914

PERMIT NUMBER:

11 271495

TYPE OF WINDOW

DOUBLE HUNG

NUMBER OF WINDOWS

1

Total Glazed Area Minimum 5 Square Feet	6.7 sq.ft	Difference from Required Area	+ 1.7 sq.ft.
Width of Opening Minimum 20 Inches	25"	Difference from Required Opening	+ 5"
Height of Opening Minimum 24 Inches	19"	Difference from Required Opening	- 5"
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	ОК	Difference from Maximum Height	ОК

COMMENTS: Based on information provided above determination to be made by the legislative hearing officer

Reviewed by: jps