



RLH FOW 11-80
APPLICATION FOR APPEAL

RECEIVED
JUN 21 2011
CITY CLERK

Saint Paul City Clerk
310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:
Tuesday, <u>July 12</u> , June 28 , 2011
Time <u>1:30 p.m.</u>
Location of Hearing:
<u>Room 330 City Hall/Courthouse</u>

Called 6-21-11 okay with date
mailed 6-21-11

Address Being Appealed:

Number & Street: 419 Michigan St. City: St. Paul State: Mn Zip: 55102

Appellant/Applicant: Bonnie Hammer Email Bonnieh26@comcast.net

Phone Numbers: Business _____ Residence 651-644-2984 Cell 651-307-9456

Signature: Bonnie Hammer Date: 6/20/11

Name of Owner (if other than Appellant): _____

Address (if not Appellant's): 1857 Laurel Ave, St. Paul, Mn 55104

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

Item #2 on deficiency list -- The house is over 100 years old. The window is only deficient in operable height, it exceeds operable width by 4.5 inches.



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

*375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806*

*Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi*

June 15, 2011

BONNIE J HAMMER
1857 LAUREL AVE
ST PAUL MN 55104-5938

FIRE INSPECTION CORRECTION NOTICE

RE: 419 MICHIGAN ST
Ref. #114102
Residential Class: B

Dear Property Representative:

Your building was inspected on June 15, 2011 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date. A re-inspection will be made on July 29, 2011 at 9:30am.

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

DEFICIENCY LIST

1. BASEMENT - SPLC 34.11 (4), 34.34 (1), MPC 4515, MPC 326 - Connect or cap the sewer piping in accordance with the plumbing code.-Washing machine and tub is not properly connected to the waste lines.

2. SECOND FLOOR - NORTH BEDROOM - MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651) - 266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information. **-Window measures 16.75 inches openable height x 24.5 openable width. Net glazed area is 6.0 square feet.**
3. SECOND FLOOR - SPLC 34.11, SBC 2902.1, SPLC 34.17, MPC 415.0220 - Repair or replace and maintain the plumbing fixture to an operational condition. -Repair or replace and maintain an approved private tub or shower. This work may require a permit(s). Call LIEP at (651) 266-9090.
4. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.
5. SPLC 39.02(c) - Complete and sign the provided smoke detector affidavit and return it to this office.
6. MN State Statute 299F.50 Immediately provide and maintain an approved Carbon Monoxide Alarm in a location within ten (10) feet of each sleeping area. Installation shall be in accordance with manufacturers instructions.

For an explanation or information on some of the violations contained in this report, please visit our web page at: <http://www.ci.stpaul.mn.us/index.aspx?NID=211>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: adrian.neis@ci.stpaul.mn.us or call me at 651-266-8992 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

A.J. Neis
Fire Inspector

Reference Number 114102