

✓ Scanned



CITY OF SAINT PAUL  
INTERDEPARTMENTAL MEMORANDUM

RECEIVED  
OCT 12 2011  
CITY CLERK

No. 8724 P. 2

**EGRESS WINDOW NON-COMPLIANCE DETERMINATION**

TO: CITY CLERK  
15 KELLOGG BLVD. WEST  
310 CITY HALL  
SAINT PAUL, MN 55102

PHONE: 651-266-8688  
FAX: 651-266-8574

DATE: 10-12-11

APPEAL PROPERTY ADDRESS: 1171 DALE ST

APPLICANT NAME: PUBLIC HEALTH (DANIEL) PHONE NUMBER: 266-1143  
ON BEHALF OF MOHAMED OSMAN

Public Health  
St Paul-Ramsey Co.

PERMIT NUMBER: \_\_\_\_\_

TYPE OF WINDOW: Vinyl

NUMBER OF WINDOWS: 2

TOTAL GLAZED AREA: 6.9 sqft

DIFFERENCE FROM REQUIRED AREA: COMPLIES

WIDTH OF OPENING: 19"

DIFFERENCE FROM REQUIRED OPENING: 1"

HEIGHT OF OPENING: 20"

DIFFERENCE FROM REQUIRED OPENING: 4"

HEIGHT OF OPENING  
TO FINISHED FLOOR: 248"

DIFFERENCE FROM MAXIMUM HEIGHT: COMPLIES

RECOMMENDATION (IF APPLICABLE): \_\_\_\_\_

Oct. 12. 2011, 3:13PM

FROM: \_\_\_\_\_

Oct. 12. 2011 3:13PM St Paul-Ramsey Co. Public Health No. 8724 P. 3

Select a Model


(Model 0201) Excalibur Double Hung		0201	Min. W: 11	Max W: 12	Max U/I: 132
			Min. H: 20	Max H: 64	
Top Sash Width	20.5000	Exact Size			
Top Sash Height	25.2500	Width: 23.75	23.75		
Bottom Sash Width	21.5000	Height: 53.625	53.625		
Bottom Sash Height	26.2500				
Top Glass Width	18.8125	Erection: Select Extrusion << For Arch-Top Models Only			
Top Glass Height	23.8925	Opening: Exact Size			
Bottom Glass Width	19.8125	Type: Standard			
Bottom Glass Height	24.8625	Screen: Full			
Screen Width	20.0625	Glass: Double Strength (3 mm)			
Screen Height	60.7500	<input type="checkbox"/> AC Sash Calculator			
Top Sash Weight (Plus 3 lb)	17 lb				
Top Balance Size (C.F.)	9NAT				
Top Balance Size (Spiral)	21-7R				
Bottom Sash Weight	14 lb				
Bottom Balance Size (C.F.)	7GN				
Bottom Balance Size (Spiral)	23-8R				
Egress Opening Width	19.3440				
Egress Opening Height	20.6625				
Egress Opening Area (sq.ft.)	2.8950				

\* 20

→

\*  $20 \times 50.7 = 1014 \div 144 = 7.04 \text{ sq ft}$

10-25-11  
1:30



Saint Paul - Ramsey County Department of Public Health  
Environmental Health Section  
2785 White Bear Avenue North Suite 350  
Maplewood, MN 55109-1320  
FAX: (651) 266-1177

Date: 9-23-11

To FAX#: 6-8574

Oct. 12, 2011 3:13PM — St Paul-Ramsey Co. Public Health No. 8724 P. 1

FACSIMILE TRANSMISSION  
Cover Sheet and Transmittal Form

To:	<u>Mai Yang, Paralegal</u>
Location:	<u>Legislative Hearing Office</u> <u>City of St. Paul</u>
Sender:	<u>Daniel Schmidt / Tim Yannarelli</u> <u>St. Paul - Ramsey Cty. Dept. of Public Health</u>

This transmission consists of 3 pages (including cover sheet).

If transmission is incomplete or illegible, call sender at (651) 266-1143 (DANIEL SCHMIDT)

Message:

Request for Egress Window Non-Compliance Determination

Attachments: Egress Window Non-Compliance Determination Form

**CONFIDENTIALITY NOTICE**

The document(s) accompanying this facsimile transmission may contain confidential information intended only for the use of the recipient named above. If you are not the intended recipient, you are hereby notified that any disclosure, copying or distribution of the contents of this transmission except its direct delivery to the intended recipient is strictly prohibited. If you have received this transmission in error, please notify us immediately by telephone to arrange for return of the original message to us.