

(if cash: receipt number\_

The City Clerk needs the following to process your appeal:

\$25 filing fee payable to the City of Saint Paul

# RLH VO \\-\\4 APPLICATION FOR APPEAL

### Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd. Saint Paul, Minnesota 55102 Telephone: (651) 266-8560

YOUR HEARING Date and Time:

Attachments you may wish to include This appeal form completed  Walk-In OR		Tuesday, Dec. le, 201)  Time
Address Being Appeal	ed:	
Number & Street: 1049 M. Ahali this Shalithic	Mary/and City: S Harut Tenant	State: MN Zip: 55/06  +, Family Member)  nail Mantahalithia (a) yahoo. Cam
Phone Numbers Business Same Signature: Malithia Va	Residence San	Cell (6/2)290-8203  Date: 1//22///
Name of Owner (if other than Appellant):	Santrell &	Smith
Address (if not Appellant's): 1049	Maryland 1	Ave
Phone Numbers: Business	Residence	Cell
What Is Being Appeals  Vacate Order/Condemnation/ Revocation of Fire C of O  Summary/Vehicle Abatement  Fire C of O Deficiency List  Fire C of O: Only Egress Windows  Code Enforcement Correction Notice  Vacant Building Registration  Other		Attachments Are Acceptable
- Other		



CITY OF SAINT PAUL Christopher B. Coleman, Mayor 375 Jackson Street, Suite 220 Saint Paul, Minnesota 55101-1806 

 Telephone:
 651-266-8989

 Facsimile:
 651-266-8951

 Web:
 www.stpaul.gov/dsi

November 17, 2011

SANTREL M SMITH 1911 SUBURBAN AVE APT 120 ST PAUL MN 55119-7003

#### Revocation of Fire Certificate of Occupancy and Order to Vacate

RE: 1

1049 MARYLAND AVE E

Ref. # 117020

Dear Property Representative:

Your building was inspected on November 15, 2011, for the renewal of the Certificate of Occupancy. Since you have failed to comply with the applicable requirements, it has become necessary to revoke the Certificate of Occupancy in accordance with Section 33.05 of the Saint Paul Legislative Code.

#### A reinspection will be made on December 5, 2011 at 1:00 pm or the property vacated.

The Saint Paul Legislative Code further provides that no building shall be occupied without a Certificate of Occupancy. Failure to immediately complete the following deficiency list or the building vacated may result in a criminal citation.

#### **DEFICIENCY LIST**

- 1. 1st and 2nd Floor MN State Statute 299F.50 Immediately provide and maintain an approved Carbon Monoxide Alarm in a location within ten (10) feet of each sleeping area. Installation shall be in accordance with manufacturers instructions.
- 2. 2nd Floor MSFC1026.1 Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651)- 266-9090. Refer to the Escape Windows for Residential Occupanices handout for more information.-Casement window Height 33 in Width 13.5 in.

Glazed area Height 31.5 in - Width 18 in.

3. Basement - Bath - MSFC 605.6 - Provide electrical cover plates to all outlets, switches and junction boxes where missing.-Light switch

- 4. Basement Bath SPLC 34.11, SBC 2902.1, SPLC 34.17, MPC 4715.0200.C Provide an approved number and type of plumbing fixtures.-Shower head and knob.
- 5. Basement Bedroom SPLC 34.10 (7), 34.33 (6) Repair and maintain the floor in an approved manner.
- 6. Basement Bedroom SPLC 34.10 (7), 34.33 (6) Repair and maintain the walls in an approved manner.-Hole in wall with water leaking out.
- 7. Basement UMC 504.6 Provide, repair or replace the dryer exhaust duct. Exhaust ducts for domestic clothes dryers shall be constructed of metal and shall have a smooth interior finish. The exhaust duct shall be a minimum nominal size of four inches (102 mm) in diameter. This work may require a permit(s). Call DSI at (651) 266-8989.-PERMIT REQUIRED AND INSPECTION BY WARM AIR / VENT INSPECTOR. CALL 266-9006
- 8. West bedroom SPLC 34.09 (3), 34.32 (3) Repair and maintain the window in good condition.-Window does not stay open.
- 9. SPLC 34.11 (6), 34.34 (3) Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.
- 10. SPLC 39.02(c) Complete and sign the provided smoke detector affidavit and return it to this office.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: http://www.stpaul.gov/cofo

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: mike.cassidy@ci.stpaul.mn.us or call me at 651-266-8984 between 7:30 - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Mike Cassidy Fire Inspector

Ref. # 117020

## By Order of the City of Saint Paul Department of Safety & Inspections Fire Inspection Division 651- 266- 8989

## REVOCATION NOTICE

The Fire Certificate of Occupancy Required for

The Occupancy or Use of This Building, Has been
Revoked. It is unlawful to Use or Occupy this Building After:
Persons Using or Allowing the Use or Occupancy of This Building are Subject to Criminal Penalties.
Building Address: 1049 Maryland Ave E
Code: Ma FC , Art.: 4 , Sect. 40.06
Code: Mn FC , Art.: 4 , Sect. 40.06 Inspector: M. Cassilly , Date: 11/17/11
266- 2004

Any Person affected by this Order, may file an appeal at the Office of the City Clerk, Room 310, City Hall, 15 Kellogg Blvd. West, or call (651) 266-8688 within 10 days of the original notice. The cost to file an appeal is \$25.00 and must include a copy of the letter of revocation. This letter of revocation is available at: Saint Paul Department of Safety & Inspections, Fire Inspection Division, 375 Jackson Street Suite #200 Saint Paul, MN 55101