



CITY OF SAINT PAUL
OFFICE OF THE CITY COUNCIL
310 CITY HALL
15 WEST KELLOGG BOULEVARD
SAINT PAUL, MN 55102-1615
EMAIL: legislativehearings@ci.stpaul.mn.us
PHONE: (651) 266-8560 FAX: (651) 266-8574

November 21, 2011

Penny
Installation Masters, Inc.
o/b/o Tony & Katy Harms
Installation Masters Inc
359 Wyldwood Ln
Spring Lake Park MN 55432-0000

VIA EMAIL: penny@installationmastersinc.com

Re: Appeal for property at 1013 Grotto Street North

Dear Penny:

This is to confirm that Marcia Moermond, Legislative Hearing Officer, reviewed the above-referenced matter and recommended that the City Council grant a 3-inch variance on the openable width of three replacement egress bedroom windows measuring 17 inches wide by 36 and 28 inches high.

The City Council Public Hearing is scheduled for Wednesday, December 21, 2011 at 5:30 p.m. in Room 300 Council Chambers. You don't need to attend this hearing since the appeal has been granted.

If you have any further questions, you may contact me at 651-266-8563.

Sincerely,

/s/

Mai Vang
Legislative Hearing Coordinator

cc: Fire Supervisors (email)
Jim Bloom (email)
Stephen Ubl (email)
Virgil Thomas (email)