



APPLICATION FOR APPEAL

RECEIVED

NOV 28 2011

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- ☒ \$25 filing fee payable to the City of Saint Paul
(if cash: receipt number _____)
- ☒ Copy of the City-issued orders or letter which
are being appealed
- ☐ Attachments you may wish to include
- ☐ This appeal form completed
- ☐ Walk-In OR ☒ Mail-In

YOUR HEARING Date and Time:

Tuesday, 12-13-11

Time 1:30

Location of Hearing:

Room 330 City Hall/Courthouse

emailed 11-28-11

Address Being Appealed:

Number & Street: 2099 PINEHURST AV City: ST. PAUL State: MN Zip: 55116

Appellant/Applicant: KEVEN STEEN/WELLINGTON WINDOW Email KSteen@wellingtonwindow.com

Phone Numbers: Business 952-933-6300 Residence _____ Cell 952-451-5412

Signature: *Kevin Steen* Date: 9-12-11

Name of Owner (if other than Appellant): KENDRA LIU

Address (if not Appellant's): _____

Phone Numbers: Business _____ Residence 651-295-9767 Cell _____

What Is Being Appealed and Why? *Attachments Are Acceptable*

- ☐ Vacate Order/Condemnation/
- ☐ Revocation of Fire C of O
- ☐ Summary/Vehicle Abatement
- ☐ Fire C of O Deficiency List
- ☒ Fire C of O: Only Egress Windows
- ☐ Code Enforcement Correction Notice
- ☐ Vacant Building Registration
- ☐ Other

ONE WINDOW DOES NOT MEET THE
MINIMUM HEIGHT REQUIREMENT.



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: March 3, 2011

APPEAL PROPERTY ADDRESS: 2099 PINEHURST AVE

APPLICANT NAME: WELLINGTON WINDOW & DOOR COMPANY

PHONE NUMBER:

PERMIT NUMBER: 11 008677

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 1 Bedroom

Total Glazed Area Minimum 5 Square Feet	6.5 sq. ft.	Difference from Required Area	+1.5 sq. ft. ok
Width of Opening Minimum 20 Inches	24"	Difference from Required Opening	+4" ok
Height of Opening Minimum 24 Inches	20"	Difference from Required Opening	-4"
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	28"	Difference from Maximum Height	+20"ok

COMMENTS:

Reviewed by: David Tank