



## CITY OF SAINT PAUL

### OFFICE OF THE CITY COUNCIL

310 CITY HALL

15 WEST KELLOGG BOULEVARD

SAINT PAUL, MN 55102-1615

EMAIL: [legislativehearings@ci.stpaul.mn.us](mailto:legislativehearings@ci.stpaul.mn.us)

PHONE: (651) 266-8560 FAX: (651) 266-8574

January 27, 2012

### REVISED LETTER

Daniel Schmidt  
RC Public Health  
2875 White Bear Ave N, Ste. 350  
Maplewood MN 55109

VIA EMAIL: [daniel.schmidt@co.ramsey.mn.us](mailto:daniel.schmidt@co.ramsey.mn.us)

Re: Appeal for property at 1699 Case Avenue

Dear Mr. Schmidt:

This is to confirm that Marcia Moermond, Legislative Hearing Officer, reviewed the above-referenced appeal and recommended that the City Council grant a 2-inch variance on the openable height of two double hung replacement egress bedroom windows measuring 22 inches high by 23.3 inches wide and grant a 4-inch variance on the openable height of one double hung replacement egress bedroom window measuring 20 inches high by 26.8 inches wide.

The City Council Public Hearing is scheduled for Wednesday, February 15, 2012 at 5:30 p.m. in Room 300 Council Chambers; however, you don't need to attend since the appeal has been granted.

If you have any further questions, you may contact me at 651-266-8563.

Sincerely,

/s/

Mai Vang  
Legislative Hearing Coordinator

cc: Fire Supervisors (email)  
Jim Bloom (email)  
Stephen Ubl (email)