



RLH FCO 12-19 APPLICATION FOR APPEAL

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

RECEIVED

DEC 30 2011

CITY CLERK

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed
- Walk-In OR Mail-In

YOUR HEARING Date and Time:

Tuesday, 1/24/2012

Time 1:30 P.M.

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 698 Holly Ave City: St. Paul State: MN Zip: 55104

Appellant/Applicant: Marty Long Email _____

Phone Numbers: Business _____ Residence _____ Cell 651-738-7191

Signature: [Signature] Date: 12-30-11

Name of Owner (if other than Appellant): _____

Address (if not Appellant's): 4824 Eagle Hill Dr, Hugo, MN 55038

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being Appealed and Why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O _____
- Summary/Vehicle Abatement _____
- Fire C of O Deficiency List _____
- Fire C of O: Only Egress Windows _____
- Code Enforcement Correction Notice _____
- Vacant Building Registration _____

Other SPLC 34.09 - exterior painting

Fire inspection requiring exterior to be scraped and painted if bare spots. (see attached)



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.sipaul.gov/dsi

November 29, 2011.

MARTY LONG
JENNIFER LONG
4824 FABLE HILL PKWY N
HUGO MN 55038

FIRE INSPECTION CORRECTION NOTICE

RE: 698 HOLLY AVE
Residential Class: C

Dear Property Representative:

Your building was inspected on November 28, 2011 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date. A re-inspection will be made on January 3, 2012 at 10:00 AM.

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

DEFICIENCY LIST

1. Basement steps - SPLC 34.10 (3), 34.33(2) - Provide an approved handrail. The top of the handrail must be between 34 and 38 inches above the treads and run the entire length of the stair.
2. Basement steps - SPLC 34.10 (3) 34.33(2) - Provide an approved guardrail. Intermediate balustrade must not be more than 4 inches apart. Intermediate rails must be provided if the height of the platform is more than 30 inches.
3. Garage - facing the alley - SPLC 71.01 - The address posted is not visible from street. (HN-1)

4. Lower level - Behind refrigerator - MSFC 605.6 - Provide electrical cover plates to all outlets, switches and junction boxes where missing.
5. Second floor - Rear exterior porch - SPLC 34.09 (2) 34.32 (2) - Provide an approved guardrail with intermediate ballustrade or rails 4 inches or less apart. This work may require a permit(s). Call DSI at (651) 266-9090.-Current guardrail is 29 inches.
6. Second floor - Rear hallway - MSFC 1011.2 - Remove the materials that cause an exit obstruction. Maintain a clear and unobstructed exitway.
7. SPLC 39.02(c) - Complete and sign the provided smoke detector affidavit and return it to this office.
8. MN State Statute 299F.50 Immediately provide and maintain an approved Carbon Monoxide Alarm in a location within ten (10) feet of each sleeping area. Installation shall be in accordance with manufacturers instructions.
9. SPLC 34.09 (1) b,c, 34.32 (1) b,c - Provide and maintain all exterior free from holes and deterioration. All wood exterior unprotected surfaces must be painted or protected from the elements and maintained in a professional manner free from chipped or peeling paint.-Scrape and remove chipped and peeling paint. Repaint in a professional manner.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd. Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: rick.gavin@ci.stpaul.mn.us or call me at 651-266-8994 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Rick Gavin
Fire Inspector