FEB 0 6 2012

Revised 3/7/2011



The City Clerk needs the following to process your appeal:

APPLICATION FOR APPEAL

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd. Saint Paul, Minnesota 55102 Telephone: (651) 266-8560

| \$25 filing fee payable to the City of Saint Paul (if cash: receipt number) Copy of the City-issued orders or letter which are being appealed Attachments you may wish to include This appeal form completed Walk-In OR Mail-In | YOUR HEARING Date and Time: Tuesday, 2-21-12 Time 1.30 Location of Hearing: Room 330 City Hall/Courthouse |
|--|--|
| Address Being Appealed: | |
| Number & Street: 2051 Nortonia St City: | St. Paul State: MN Zip: 55119 |
| Appellant/Applicant: Home Depot at home Service | SEmail <u>Mknoll@THDathomeScr</u> V |
| Phone Numbers: Business 163-852-1044 Residence | Cell 763-238-6949 |
| | Date: 1-23-20/2 |
| Name of Owner (if other than Appellant): Tustin Vi | • |
| Address (if not Appellant's): 2051 Nortonia | St. St. R.C. |
| Phone Numbers: Business Residence | Cell |
| What Is Being Appealed and Why | ? Attachments Are Acceptable |
| Vacate Order/Condemnation/ Revocation of Fire C of O | |
| Summary/Vehicle Abatement | |
| Fire C of O Deficiency List | |
| Fire C of O: Only Egress Windows | |
| Code Enforcement Correction Notice Egress whele | w compliance |
| □ Vacant Building Registration | Secret of the second |
| □ Other | |

PHONE: 651-266-8688

651-266-8574

FAX:

Attention Simon



CITY OF SAINT PAUL INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DÉTERMINATION

TO: CITY CLERK

₹15 KELLÒGG BLVD. WEST

310 CITY HALL

SAINT PAUL, MN 55102

DATE: November 2, 2011

APPEAL PROPERTY ADDRESS:

2051 NORTONIA AVE

APPLICANT NAME:

HOME DEPOT AT HOME SERVICES THE

PHONE NUMBER:

770-779-1300

PERMIT NUMBER:

10 913700

TYPE OF WINDOW

Double Hung

NUMBER OF WINDOWS

One

| Total Glazed Area | 7.1 sq.ft. | Difference from Required Area | +1.4 sq. ft. |
|--|------------|----------------------------------|--------------|
| Minimum 5 Square Feet | | | |
| Width of Opening | 31" | Difference from Required Opening | +11* |
| Minimum 20 Inches | | | |
| Height of Opening | 12" | Difference from Required Opening | -12" |
| Minimum 24 Inches | | | |
| Height of Opening | ОК | Difference from Maximum Height | |
| to Finished Floor | | | |
| Maximum 48 Inches for Existing Openings | | | |

COMMENTS:

Please Resolve His order!

Reviewed by:

David Nelson

266 9027