

APPLICATION FOR APPEAL

RECEIVED FEB 0 7 2012 GITY GLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd. Saint Paul, Minnesota 55102 Telephone: (651) 266-8560

The City Clerk needs the following to pr	rocess your appeal:					
\$25 filing fee payable to the City of (if cash: receipt number) Copy of the City-issued orders or le are being appealed Attachments you may wish to inclu This appeal form completed Walk-In OR Mail-In	YOUR HEARING Date and Time: tter which Tuesday, Feb. 21, 2012					
Address Being Appealed:						
The Care	SIDING PROFESSIONALS Email CONT @ tosiding professionals.					
Phone Numbers: Business 651 255 2	Residence Cell 657 497 0069 Date: 2-6-17					
Name of Owner (if other than Appellant): MARY + VIC BOWMAN						
Address (if not Appellant's):						
Phone Numbers: Business	Residence 451 403 8200 Cell					
What Is Being Appealed and Why? Attachments Are Acceptable						
Vacate Order/Condemnation/ Revocation of Fire C of O Summary/Vehicle Abatement Fire C of O Deficiency List Fire C of O: Only Egress Windows Code Enforcement Correction Notice Vacant Building Registration	New windows have been installed in the home. One bedroom has two windows, and the larger window almost is compliant (see attached). Twin Cities Siding Professionals					
□ Other	Customer Focused ► Employee Driven					

664 Transfer Road, St.Paul, MN 55114

Revised 3/7/2011

CITY OF SAINT PAUL INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK

PHONE: 651-266-8688

15 KELLOGG BLVD. WEST

FAX: 651-266-8574

310 CITY HALL

SAINT PAUL, MN 55102

DATE: February 2, 2012

APPEAL PROPERTY ADDRESS: 1827 ELEANOR AVE

APPLICANT NAME:

TWIN CITIES SIDING PROFESSIONALS INC

PHONE NUMBER:

651-255-2844

PERMIT NUMBER:

11 309445

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 2 windows in same bedroom same size.

Total Glazed Area	5.1	Difference from Required Area	.06
Minimum 5 Square Feet			
Width of Opening	27"	Difference from Required Opening	3"
Minimum 20 Inches			

Height of Opening	17.5	Difference from Required Opening	2.5"
Minimum 24 Inches			
Height of Opening to Finished Floor	34"	Difference from Maximum Height	10"
Maximum 48 Inches for Existing Openings			

COMMENTS: At least one window in the bedroom should meet code.

Reviewed by: Michael A. Palm