



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

Sent 1-26
DS

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: 1-26-12

APPEAL PROPERTY ADDRESS: 1108 6TH ST

APPLICANT NAME: PUBLIC HEALTH (DANIEL SCHMIOT) PHONE NUMBER: 651-266-1143

PERMIT NUMBER: _____

TYPE OF WINDOW: DH

NUMBER OF WINDOWS: 2

TOTAL GLAZED AREA: 8.38 sqft DIFFERENCE FROM REQUIRED AREA: COMPLIES

WIDTH OF OPENING: 23.21" DIFFERENCE FROM REQUIRED OPENING: COMPLIES

HEIGHT OF OPENING: 19.87 DIFFERENCE FROM REQUIRED OPENING: 4.13"

HEIGHT OF OPENING TO FINISHED FLOOR: < 48" DIFFERENCE FROM MAXIMUM HEIGHT: COMPLIES

RECOMMENDATION (IF APPLICABLE): _____

FROM: _____

Select a Model

(Model 0201)		0201	Min. W: 11	Max W: 52	Max UI: 132
Excalibur Double Hung			Min. H: 20	Max H: 84	
Top Sash Width	24.3750		Exact Size		
Top Sash Height	25.0625		Width: 27.625	27.625	
Bottom Sash Width	25.3750		Height: 53.25	53.25	
Bottom Sash Height	28.0625		Extrusion: Select Extrusion ▼ << For Arch-Top Models Only		
Top Glass Width	22.6875		Opening: Exact Size ▼		
Top Glass Height	23.3750		Type: Standard ▼		
Bottom Glass Width	23.6875		Screen: Full ▼		
Bottom Glass Height	24.3750		Glass: Double Strength (3 mm) ▼		
Screen Width	23.9375		<input type="checkbox"/> AC Sash Calculator		
Screen Height	50.3750	<i>TOTAL GLAZED</i>			
Top Sash Weight (Plus 5 lb)	20 lb				
Top Balance Size (C.F)	55RD				
Top Balance Size (Spiral)	21-7B				
Bottom Sash Weight	16 lb				
Bottom Balance Size (C.F)	8LG				
Bottom Balance Size (Spiral)	25-6R				
Egress Opening Width	23.2190				
Egress Opening Height	19.8750				
Egress Opening Area (sq.ft.)	3.2050				

* $23.97 \times 50.37 = 1,207 \div 144 = 8.38 \text{ sq ft}$