

APPLICATION FOR APPEAL

Saint Paul City Clerk

RECEIVED
MAR 1 3 2012

310 City Hall, 15 W. Kellogg Blvd. Saint Paul, Minnesota 55102 Telephone: (651) 266-8560

CITY CLERK

The City Clerk needs the following to process	s your appeal:
\$25 filing fee payable to the City of Saint (if cash: receipt number) Copy of the City-issued orders or letter ware being appealed Attachments you may wish to include This appeal form completed Walk-In OR Mail-In	YOUR HEARING Date and Time:
Address Being Appealed	
Number & Street: 1239 E	74h City: St- Paul State: MN zip: 55/06
Appellant/Applicant: KOBIN C	HUHEL Email ROBIN CHUHEL@gmail.co
	Residence Cell 6513578305 Date: 3 - 13 - 2012
Name of Owner (if other than Appellant):	
Address (if not Appellant's):	
Phone Numbers: Business	Residence Cell
What Is Being Appealed	and Why? Attachments Are Acceptable
Vacate Order/Condemnation/ Revocation of Fire C of O Summary/Vehicle Abatement Fire C of O Deficiency List Fire C of O: Only Egress Windows Code Enforcement Correction Notice Vacant Building Registration Other	ST OF repairs



CITY OF SAINT PAUL Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220 Saint Paul, Minnesota 55101-1806

 Telephone:
 651-266-8989

 Facsimile:
 651-266-8951

 Web:
 www.stpaul.gov/dsi

March 8, 2012

Robin K Chuhel 9045 Glacier Bay Woodbury MN 55125-3468

RE: RE-INSPECTION FIRE CERTIFICATE OF OCCUPANCY WITH DEFICIENCIES 1239 7TH ST E

Ref. # 111753

Dear Property Representative:

Your building was re-inspected for the Fire Certificate of Occupancy on March 8, 2012. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected immediately. A reinspection will be made on April 9, 2012 at 1:30 P.M..

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional reinspection fees.

DEFICIENCY LIST

- 1. 2nd floor MSFC 703 Provide and maintain fire rated wall construction with approved materials and methods. This work may require a permit(s). Call DSI at (651) 266-9090. The minimum rating must be: 1 Hour
- 2. 2nd floor MSFC 703 Provide and maintain fire rated floor and/or ceiling construction with approved materials and methods. This work may require a permit(s). Call DSI at (651) 266-9090. The minimum rating must be: 1 hour
- 3. 3rd floor MSFC 703 Provide and maintain fire rated floor and/or ceiling construction with approved materials and methods. This work may require a permit(s). Call DSI at (651) 266-9090. The minimum rating must be: 1hour
- 4. 4th floor SPLC 34.11, SBC 2902.1, SPLC 34.17, MPC 415.0220 Repair or replace and maintain the plumbing fixture to an operational condition.-Repair or replace and maintain an approved private toilet. Secure toilet to floor

- 5. Basement MFGC-Sec 303.3 Prohibited Location for Appliances. Appliances shall not be located in sleeping rooms bathrooms toilet rooms storage closets or surgical rooms in
- space that opens only into such rooms or spaces except where installation complies with one of the following: # 5.-#5 applies to you. You have begun to structure the one with a one hour rating with a door equipped with an approved self closing device. The walls and ceiling 1 hour rating must be completed.
- 6. Basement MSFC 703 Provide and maintain fire rated floor and/or ceiling construction with approved materials and methods. This work will require a permit(s). Call DSI at (651) 266-9090. The minimum rating must be: 1 hour
- 7. Chimney is cracked and has open mortar joints. MSFC SEC603.1 Masonry Chimneys. Masonry chimneys that upon inspection are found to be without a flue liner and that have OPEN MORTAR JOINTS which will permit smoke or gases to be discharged into the building or which are CRACKED as to be dangerous shall be repaired or relined with a listed chimney liner system installed in accordance with the manufacturers installation instructions.
- 8. House MSFC 605.6 Provide electrical cover plates to all outlets, switches and junction boxes where missing.-Various locations
- 9. House MSFC 605.5 Discontinue use of extension cords used in lieu of permanent wiring.-various locations
- 10. House SBC 3405.1, SBC 110.2 The occupancy group or use division of this building has been changed from that previously approved. Discontinue the unapproved occupancy or use, or contact the Building Official at 651-266-9071 for a code analysis and to comply with requirements for approved occupancy.
- House SPLC 62.101 Use of this property does not conform to zoning ordinance. Discontinue unapproved use or call DSI Zoning at (651) 266-8989 to convert to legal use. Discontinue: As a four plex-There are three units in the interior of the building, there is a fourth unit in the rear north side of building.
- 12. Steps attached to House SPLC 34.09 (2) 34.32 (2) Provide an approved handrail. The top of the handrail must be between 34 and 38 inches above the treads and run the entire length of the stair.
- 13. SPLC 34.11 (6), 34.34 (3) Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.
- 14. SPLC 39.02(c) Complete and sign the provided smoke detector affidavit and return it to this office.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: http://www.stpaul.gov/cofo

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of the original orders.

If you have any questions, email me at james.thomas@ci.stpaul.mn.us or call me at 651-266-8983 between 7:30 a.m - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

James Thomas Fire Inspector Ref. # 111753