



APPLICATION FOR APPEAL

RECEIVED Saint Paul City Clerk
MAR 28 2012 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
CITY CLERK Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed
- Walk-In OR Mail-In

YOUR HEARING Date and Time:

Tuesday, 4-10-12

Time 1:30 P.M.

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 1126 E. St Paul Ave City: St. Paul State: MN Zip: 55117

Appellant/Applicant: Equitron Holdings LLC Email rayabdurakhimov@gmail.com

Phone Numbers: Business 651 216 6008 Residence _____ Cell 651 216 6008

Signature: [Signature] Date: 03/26/2012

Name of Owner (if other than Appellant): _____

Address (if not Appellant's): _____

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being Appealed and Why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other

Was approved by prior inspection
(had to cut windowsill)



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

March 22, 2012

EQUITRON HOLDINGS LLC
2929 Chicago Ave S Ste 1003
Minneapolis MN 55407-4325

FIRE INSPECTION CORRECTION NOTICE
Rescheduled Appointment

RE: 1186 ST PAUL AVE
Residential Class: C

Dear Property Representative:

Your building was inspected on March 5, 2012 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date.

A re-inspection will be made on April 9, 2012 at 12:45 PM.

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

DEFICIENCY LIST

1. Basement - SPLC 34.09 (3), 34.32 (3) - Repair and maintain the window in good condition.-Repair window crank mechanism in an approved manner.
2. Basement and first floor east bedroom - MN Stat. 299F.362 - Immediately provide and maintain a smoke detector located outside each sleeping area.
3. Exterior - East side of deck - SPLC 34.09 (3), 34.32 (3) - Repair and maintain the door in good condition.
4. Exterior - SPLC 34.09 (1) b,c, 34.32 (1) b,c - Provide and maintain all exterior walls free from holes and deterioration. All wood exterior unprotected surfaces must be painted or

An Equal Opportunity Employer

protected from the elements and maintained in a professional manner free from chipped or peeling paint.-Scrape and remove chipped and peeling paint. Repaint in a professional manner.

5. First floor east - Double hung - MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651)- 266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information.-Window opens
20.5 h x 26.5 w Glazed 6.0 sq ft
6. Garage - MSFC 605.6 - Provide electrical cover plates to all outlets, switches and junction boxes where missing.
7. South of house - SPLC 34.08 (5), 34.31 (3) - Repair, replace and maintain all exterior surfaces on fences, sheds, garages and other accessory structures free from holes and deterioration. Provide and maintain exterior unprotected surfaces painted or protected from the elements.-Repair fence gate in an approved manner.
8. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.
9. SPLC 39.02(c) - Complete and sign the smoke detector affidavit and return it to this office.
10. SPLC 34.09 (3), 34.32 (3) - Repair and maintain the window in good condition.-Repair window crank mechanism in an approved manner.
11. MN Stat. 299F.362 - Immediately provide and maintain a smoke detector located outside each sleeping area.-Replace battery.
12. MN State Statute 299F.50 Immediately provide and maintain an approved Carbon Monoxide Alarm in a location within ten (10) feet of each sleeping area. Installation shall be in accordance with manufacturers instructions.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: rick.gavin@ci.stpaul.mn.us or call me at 651-266-8994 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Rick Gavin
Fire Inspector