


Scanned



APPLICATION FOR APPEAL

RECEIVED

MAY 08 2012

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- ☒ \$25 filing fee payable to the City of Saint Paul
(if cash: receipt number _____)
- ☒ Copy of the City-issued orders or letter which
are being appealed
- ☒ Attachments you may wish to include
- ☒ This appeal form completed
- ☒ Walk-In OR ☐ Mail-In

YOUR HEARING Date and Time:

Tuesday, 5-15-12

Time 1:30 P.M.

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 1227 3rd St E City: St Paul State: MN Zip: 55106

Appellant/Applicant: Ryan Engelhardt Email: rphardt@comcast.net

Phone Numbers: Business 651-294-8625 Residence _____ Cell 612-518-2543

Signature: [Signature] Date: _____

Name of Owner (if other than Appellant): _____

Address (if not Appellant's): _____

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being Appealed and Why?

Attachments Are Acceptable

- ☐ Vacate Order/Condemnation/
Revocation of Fire C of O
- ☐ Summary/Vehicle Abatement
- ☒ Fire C of O Deficiency List
- ☐ Fire C of O: Only Egress Windows
- ☐ Code Enforcement Correction Notice
- ☐ Vacant Building Registration
- ☐ Other

Egress Windows: House was built in 1925
Windows in bedrooms are not up to code.

Exterior Parking Surface - Renters have made
this area a parking space. Was not advertised
as a parking space. Can this be a parking spot
on dirt? If not - can we plant grass seed here
and not allow parking?

<Attached pictures>



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

May 2, 2012

RYAN ENGELHARDT
5540 38TH AVE S
MINNEAPOLIS MN 55417-2107

FIRE INSPECTION CORRECTION NOTICE

RE: 1227 3RD ST E
Ref. #115339
Residential Class: C

Dear Property Representative:

Your building was inspected on April 30, 2012 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date.

A re-inspection will be made on June 15, 2012 at 2:00pm.

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

DEFICIENCY LIST

1. Basement - Dryer vent - UMC 504.6 - Provide, repair or replace the dryer exhaust duct. Exhaust ducts for domestic clothes dryers shall be constructed of metal and shall have a smooth interior finish. The exhaust duct shall be a minimum nominal size of four inches (102 mm) in diameter. This work requires a permit(s). Call DSI at (651) 266-8989.- Remove the unapproved plastic flexible dryer exhaust duct and replace with a code compliant exhaust duct. This work must be done by licensed contractor under permit.

2. Basement - Stairway - SPLC 34.10 (3) 34.33(2) - Provide an approved guardrail. Intermediate balustrades must not be more than 4 inches apart. Intermediate rails must be provided if the height of the platform is more than 30 inches.
3. Egress Window - MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651) - 266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information.

Main Floor Southwest and Northwest Bedroom (Double-hung)

22h x 24w - Openable

48h x 24w – Glazed

4. Exterior - Parking Surface - SPLC 34.08 (7) - All parking spaces shall be paved with asphalt, concrete, or durable dustless surfacing. Before any existing spaces may be paved, site plan approval must be obtained as specified in the St. Paul Zoning Code. Contact DSI Zoning at 651-266-9090.-The parking space/driveway adjacent to the garage is dirt. Dirt is not an approved parking surface. Install an approved parking surface adjacent to the garage.
5. House and Garage - Exterior Surfaces - SPLC 34.08 (5), 34.31 (3) - Repair, replace and maintain all exterior surfaces free from holes and deterioration. Provide and maintain exterior unprotected surfaces painted or protected from the elements.-Scrape all flaking/chipped paint. Maintain all exterior surfaces in a good state of repairs and protected against elements of the weather.
6. Main Floor - Hallway - SPLC 34.12 (2), 34.35 (1) - Repair and maintain all required and supplied equipment in an operative and safe condition.-Replace the missing hard-wired smoke detector. Once hard-wired smoke detectors have been installed they must be maintained. Battery operated smoke detectors may be installed in addition to, but not in lieu of, hard-wired detectors.
7. Main Floor - Northwest Bedroom - MSFC 1011.2 - Remove the materials that cause an exit obstruction. Maintain a clear and unobstructed exitway.-Remove or reposition the dresser that is blocking the egress window.
8. Main Floor - Rear Entry - SPLC 34.10 (3), 34.33(2) - Provide an approved handrail. The top of the handrail must be between 34 and 38 inches above the treads and run the entire length of the stair.-Install the required handrail on the stairway adjacent to the kitchen.
9. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>.

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: wayne.spiering@ci.stpaul.mn.us or call me at 651-266-8993 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Wayne Spiering
Fire Inspector

Reference Number 115339