



APPLICATION FOR APPEAL

RECEIVED
MAY 07 2012
CITY CLERK

Saint Paul City Clerk
310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____) *check #1149*
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed
- Walk-In OR Mail-In

YOUR HEARING Date and Time:
Tuesday, <u>5-15-12</u>
Time <u>1:30 P.M.</u>
Location of Hearing:
<u>Room 330 City Hall/Courthouse</u>

Address Being Appealed:

(Rental)
Number & Street: 1060 Desoto St City: St Paul State: MN Zip: 55106

Appellant/Applicant: Yevgeniy Dobranovich & Anna Dvyanikova Email: ANIKOVA1@gmail.com
720-422-9591

Phone Numbers: Business _____ Residence _____ Cell 612-229-7009

Signature: [Signature] Date: 4/24/2012

Name of Owner (if other than Appellant): _____

Address (if not Appellant's): 2718 CLARE Ln, Mound, MN 55364

Phone Numbers: Business _____ Residence _____ Cell same

What Is Being Appealed and Why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows Please see #6 on report attached
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other

Anna O

From: Benjamin Ellis [Benjamin.Ellis@ci.stpaul.mn.us]
Sent: Monday, April 23, 2012 4:08 PM
To: anikova1@gmail.com
Subject: 1060 Desoto St Fire Inspection Deficiency List

April 23, 2012

ANNA OVSYANNIKOVA
2718 CLARE LN
MOUND MN 55364-1812

FIRE INSPECTION CORRECTION NOTICE

RE: 1060 DESOTO ST
Ref. #117820
Residential Class: C

Dear Property Representative:

Your building was inspected on April 23, 2012 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date.

A re-inspection will be made after May 23, 2012.

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

DEFICIENCY LIST

1. Exterior - SPLC 34.08 (5), 34.31 (3) - Repair, replace and maintain all exterior surfaces on fences, sheds, garages and other accessory structures free from holes and deterioration. Provide and maintain exterior unprotected surfaces painted or protected from the elements.-Repair and maintain retaining wall in front of building.
2. Exterior - SPLC 34.09 (3), 34.32 (3) - Provide or repair and maintain the window screens for second floor in front.
3. Interior - Basement - MSFC 605.4, 5 - Discontinue use of multiplug adapters and extension cords used in lieu of permanent wiring.
4. Interior - Basement - UMC 504.6 - Provide, repair or replace the dryer exhaust duct. Exhaust ducts for domestic clothes dryers shall be constructed of metal and shall have a smooth interior finish. The

exhaust duct shall be a minimum nominal size of four inches (102 mm) in diameter. This work may require a permit(s). Call DSI at (651) 266-8989.

5. Interior - Bathroom - SPLC 34.14 (2) c - Provide or replace the duplex convenience outlet with ground fault protection within 3 feet of the basin on an adjacent wall in all bathrooms. This work may require a permit(s). Call DSI at (651) 266-9090.
6. Interior - Bedroom - MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651)- 266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information.
7. Interior - SPLC 34.09 (3), 34.32 (3) - Repair and maintain the window in good condition.-Living room window does not open.
8. Interior - MN State Statute 299F.50 Immediately provide and maintain an approved Carbon Monoxide Alarm in a location within ten (10) feet of each sleeping area. Installation shall be in accordance with manufacturers instructions.
9. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.
10. SPLC 34.09 (2) 34.32 (2) - Provide an approved guardrail with intermediate balustrade or rails 4 inches or less apart. This work may require a permit(s). Call DSI at (651) 266-9090.-Back porch and basement stairway.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: benjamin.ellis@ci.stpaul.mn.us or call me at 651-266-8946 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Benjamin Ellis
Fire Inspector

Benjamin D. Ellis Sr, CFI
Fire Inspector I

Department of Safety and Inspections
Fire Inspection Division
375 Jackson St #220

Saint Paul, MN 55101

(651) 266-8946 Office

Benjamin.Ellis@ci.stpaul.mn.us

This e-mail, including attachments, may include confidential and/or proprietary information, and may be used only by the person or entity to which it is addressed. If the reader of this e-mail is not the intended recipient or his or her authorized agent, the reader is hereby notified that any dissemination, distribution or copying of this e-mail is prohibited. If you have received this e-mail in error, please notify the sender by replying to this message and delete this e-mail immediately.



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-9124
Web: www.stpaul.gov/dsi

**SMOKE AND CARBON MONOXIDE DETECTOR
INSPECTION AFFIDAVIT**

** This affidavit must be completed and returned to the fire inspector upon inspection of the property. A certificate of occupancy cannot be issued/renewed without this completed affidavit. If all the units were not inspected by one person, signatures of all persons inspecting are required. More than one sheet may be used. **

1060 Dupont St 1 _____
Address # of Units C of O #

I affirm that I have given the occupant of each dwelling unit or guest room in the building at the above address a written explanation of the following:

1. The location and operation of each smoke detector and carbon monoxide detector.
2. Instructions describing the action to be taken when an alarm sounds.
3. The procedures for testing the detectors.
4. Who to contact when a low-battery tone sounds or power light fails.
5. The penalties for disabling smoke detection or carbon monoxide detection.

Signature: [Signature] Date: 09/23/12

I affirm that I personally inspected the smoke detectors and carbon monoxide detectors in the dwelling units and guest rooms in the building at the above address as follows and that all detectors were in place and good working order:

Apt. #	Apt. #	Apt. #	Apt. #	Apt. #	Apt. #
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____

Signature: [Signature] Date: 09/23/12

Minnesota State Statutes 299F.362 requires smoke detectors and Minnesota State Statute 299F.50 requires carbon monoxide detectors and Saint Paul Ordinance 39.02 (c) requires that an affidavit stating that "all detectors are inspected and serviced when needed and are operational be filed before a Certificate of Occupancy can be issued or renewed."

Revised 12/09