

APPLICATION FOR APPEAL

MAY 0 4 2012 CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd. Saint Paul, Minnesota 55102 Telephone: (651) 266-8560

The City Clerk needs the following to process	s vour appeal:
\$25 filing fee payable to the City of Saint (if cash: receipt number) Copy of the City-issued orders or letter ware being appealed Attachments you may wish to include This appeal form completed Walk-In OR Mail-In	t Paul YOUR HEARING Date and Time:
Address Being Appealed	
	City: St. Paul State: MD Zip:55106
	tan) Email AReinton 2 1510 Hot M
•	Residence Cell
Signature: asen Reitro	Date: 5/4/12)
	no Boungart
Address (if not Appellant's):	•
Phone Numbers: Business	Residence Cell
What Is Being Appealed a	and Why? Attachments Are Acceptable
Vacate Order/Condemnation/ Revocation of Fire C of O	
□ Summary/Vehicle Abatement	
□ Fire C of O Deficiency List	
Fire C of O: Only Egress Windows	
□ Code Enforcement Correction Notice	
□ Vacant Building Registration	
□ Other	



CITY OF SAINT PAUL INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK

15 KELLOGG BLVD. WEST

310 CITY HALL

SAINT PAUL, MN 55102

DATE: May 4, 2012

APPEAL PROPERTY ADDRESS:

1513 MCAFEE ST

APPLICANT NAME:

ARDEN LARSEN

PHONE NUMBER:

651-230-2061

PERMIT NUMBER:

12 001583

TYPE OF WINDOW

Casement

NUMBER OF WINDOWS

ONE

Total Glazed Area Minimum 5 Square Feet	5.7 sq. ft.	Difference from Required Area	+.7 sq. ft.
Width of Opening Minimum 20 Inches	19.5 "	Difference from Required Opening	5"
Height of Opening Minimum 24 Inches	37"	Difference from Required Opening	+13"
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	48"	Difference from Maximum Height	OK

COMMENTS:

Reviewed by:

David Nelson

PHONE: 651-266-8688

651-266-8574

FAX: