

Saint Paul - Ramsey County Department of Public Health
Environmental Health Section
2785 White Bear Avenue North Suite 350
Maplewood, MN 55109-1320
FAX: (651) 266-1177

Date: 5-4-12

FACSIMILE TRANSMISSION
Cover Sheet and Transmittal Form

To FAX#: 6-8574

To: Mai Yang Paralegal

Location: Legislative Hearing Office
City of St. Paul

Sender: Daniel Schmidt / Tim Hannareilly
St. Paul - Ramsey Cty. Dept. of Public Health

This transmission consists of 5 pages (including cover sheet).

If transmission is incomplete or illegible, call sender at (651) 266-1173 (DANIEL SCHMIDT)

Message:

Request for Egress Window Non-Compliance Determination
Attachments: Egress Window Non-Compliance Determination Form

CONFIDENTIALITY NOTICE

The document(s) accompanying this facsimile transmission may contain confidential information intended only for the use of the recipient named above. If you are not the intended recipient, you are hereby notified that any disclosure, copying or distribution of the contents of this transmission except its direct delivery to the intended recipient is strictly prohibited. If you have received this transmission in error, please notify us immediately by telephone to arrange for return of the original message to us.

RECEIVED
MAY 04 2012
CITY CLERK



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: 5-4-12

APPEAL PROPERTY ADDRESS: 751 Cottage Avenue

APPLICANT NAME: Rubie Heath (Daniel Schmidt) PHONE NUMBER: 266-1143

PERMIT NUMBER: _____

TYPE OF WINDOW: DH

NUMBER OF WINDOWS: 2

TOTAL GLAZED AREA: 8.4 sqft DIFFERENCE FROM REQUIRED AREA: Comp


WIDTH OF OPENING: 23.2" DIFFERENCE FROM REQUIRED OPENING: Comp

HEIGHT OF OPENING: 20" DIFFERENCE FROM REQUIRED OPENING: 4"

HEIGHT OF OPENING: 248" DIFFERENCE FROM MAXIMUM HEIGHT: Comp

RECOMMENDATION (IF APPLICABLE): _____

FROM: _____



Select a Model

(Model 0201)

Excilibur Double Hung

Model

▼

Top Sash Width	24.3750
Top Sash Height	26.1875
Bottom Sash Width	25.3125
Bottom Sash Height	26.1875
Top Glass Width	22.875
Top Glass Height	22.875
Bottom Glass Width	21.875
Bottom Glass Height	24.3750
Screen Width	21.875
Screen Height	20.875
Top Sash Weight (Plus 5 lb)	20 lb
Bottom Sash Weight (Plus 5 lb)	10 lb
Top Balance Size (Steel)	21.75
Bottom Balance Size (Steel)	21.75
Bottom Balance Size (Al)	21.75
Bottom Balance Size (Special)	21.75
Screen Opening Width	23.180
Screen Opening Height	20.000
Screen Opening Area (sq ft)	3.220

Min. Wt. 11

Max. Wt. 52

Min. Ht. 20

Max. Ht. 63

Max. Lf. 132

Fixed Size

Width: 27.625

Height: 63.5

Fixed Size

Width: 27.625

Height: 63.5

Exterior Sash Position: ▼

Opening: Top Down ▼


Type: Standard ▼

Screen: 1/16" ▼

Glass: Double Strength (3 mm) ▼

☐ AC Seal Capactor

* 23.9 x 50.6 = 1209 ÷ 144 = 8.4 sq ft



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: 5-4-12

APPEAL PROPERTY ADDRESS: 751 Cottage Avenue

APPLICANT NAME: RUSHE HEIGHT (DANIEL SATTNER) PHONE NUMBER: 266-1143

PERMIT NUMBER:

TYPE OF WINDOW: CASEMENT

NUMBER OF WINDOWS: 1

TOTAL GLAZED AREA: 5.6 ft² DIFFERENCE FROM REQUIRED AREA: 0.1 ft²

WIDTH OF OPENING: 17.1" DIFFERENCE FROM REQUIRED OPENING: 2.9"

HEIGHT OF OPENING: 41.1" DIFFERENCE FROM REQUIRED OPENING: COMP

HEIGHT OF OPENING: 448" DIFFERENCE FROM MAXIMUM HEIGHT: COMP

RECOMMENDATION (IF APPLICABLE):

FROM: _____

Select a Model

(Model 0971)		Single Vent Casement	
Screen Width	22.3750	Min. Wt: 16	Max. Wt: 38
Screen Height	45.3750	Min. H: 10	Max. H: 78
Glass Width	19.3750	Max. Lb: 114	
Glass Height	44.3750		
Screen Width	19.3750		
Gross Opening Width (Standard Hinge)	41.3500		
Gross Opening Height (Standard Hinge)	41.3500		
Gross Opening Area (Standard Hinge)	41.3500		
Gross Opening Width (Slackened Hinge (sld))	31.6413		
Gross Opening Height (Slackened Hinge (sld))	17.1875		
Gross Opening Area (Slackened Hinge (sld))	41.3250		
Gross Opening Area w/Screen Hinge (sld)	4.3600		

Fixed Size	
Width:	24
Height:	45.5

Exclusion: Select Exclusion	
Opening: Select Size	<< for Amb Top Motion Only
Type: Standard	
Screen:	
Glass: Double Strength (3 mm)	

☐ AC-Side Calculator

* $40.8 \times 19.9 = 811.92 = 5.6 \text{ sq ft}$