



CITY OF SAINT PAUL

OFFICE OF THE CITY COUNCIL

310 CITY HALL

15 WEST KELLOGG BOULEVARD

SAINT PAUL, MN 55102-1615

EMAIL: legislativehearings@ci.stpaul.mn.us

PHONE: (651) 266-8560 FAX: (651) 266-8574

May 21, 2012

Daniel Schmidt
Public Health
2785 White Bear Ave N, Ste. 350
Maplewood MN 55109

VIA EMAIL: daniel.schmidt@co.ramsey.mn.us

Re: Appeal for property at 751 Cottage Avenue East

Dear Mr. Schmidt:

This is to confirm that Marcia Moermond, Legislative Hearing Officer, has reviewed the above-referenced matter and recommended that the City Council grant a 4-inch variance on the openable height of two double hung replacement egress bedroom windows measuring 20 inches high by 23.2 inches wide and grant a 2.9-inch variance on the openable width of one casement replacement egress bedroom window measuring 41.1 inches high by 17.1 inches wide.

This matter will be on the City Council Public Hearing on Wednesday, June 20, 2012 at 5:30 p.m. in Room 300 Council Chambers; however, since the appeal has been granted you don't need to appear.

If you have any further questions, you may contact me at 651-266-8563.

Sincerely,

MV

Mai Vang
Legislative Hearing Coordinator

c: Fire Supervisors (email)
Jim Bloom (email)
Stephen Ubl (email)