



APPLICATION FOR APPEAL

RECEIVED
MAY 11 2012
CITY CLERK

Saint Paul City Clerk
310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- ☐ \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- ☒ Copy of the City-issued orders or letter which are being appealed
- ☐ Attachments you may wish to include
- ☒ This appeal form completed
- ☒ Walk-In OR ☐ Mail-In

YOUR HEARING Date and Time:

Tuesday, May 22, 2012

Time 1:30 p.m.

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 2101 BURNS AVE City: ST PAUL State: MN Zip: 55106

Appellant/Applicant: J.D. NELSON CONSTRUCTION Email: JDNELSONCONSTRUCTION@HOTMAIL.COM

Phone Numbers: Business _____ Residence _____ Cell _____

Signature: [Signature] Date: _____

Name of Owner (if other than Appellant): STEVE HANSON

Address (if not Appellant's): _____

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being Appealed and Why?

Attachments Are Acceptable

- ☐ Vacate Order/Condemnation/Revocation of Fire C of O
- ☐ Summary/Vehicle Abatement
- ☐ Fire C of O Deficiency List
- ☐ Fire C of O: Only Egress Windows
- ☐ Code Enforcement Correction Notice
- ☐ Vacant Building Registration

☒ Other



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: May 11, 2012

APPEAL PROPERTY ADDRESS: 2101 BURNS AVE

APPLICANT NAME: J D NELSON CONSTRUCTION LLC

PHONE NUMBER: 651-208-2716

PERMIT NUMBER: 12 048515

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 2

Total Glazed Area Minimum 5 Square Feet	10.2	Difference from Required Area	+5.2
Width of Opening Minimum 20 Inches	36"	Difference from Required Opening	+16"
Height of Opening Minimum 24 Inches	14"	Difference from Required Opening	-10"
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	<48"	Difference from Maximum Height	ok

COMMENTS:

Reviewed by: DD 5-11-12