



APPLICATION FOR APPEAL

RECEIVED

MAY 10 2012

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- ☒ \$25 filing fee payable to the City of Saint Paul
(if cash: receipt number _____)
- ☒ Copy of the City-issued orders or letter which
are being appealed
- ☒ Attachments you may wish to include
- ☒ This appeal form completed
- ☐ Walk-In OR ☒ Mail-In

YOUR HEARING Date and Time:

Tuesday, May 22, 2012

Time 1:30 P.M.

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 902 Young Street City: St. Paul State: MN Zip: 55104

Appellant/Applicant: Lesley White-Kayser Email LWhiteKayser@gmail.com

Phone Numbers: Business 703-797-2514 Residence _____ Cell 703-969-9730

Signature: [Signature] Date: 5/7/12

Name of Owner (if other than Appellant): _____

Address (if not Appellant's): _____

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being Appealed and Why? *Attachments Are Acceptable*

- ☐ Vacate Order/Condemnation/
Revocation of Fire C of O
- ☐ Summary/Vehicle Abatement
- ☐ Fire C of O Deficiency List
- ☒ Fire C of O: Only Egress Windows
- ☐ Code Enforcement Correction Notice
- ☐ Vacant Building Registration
- ☐ Other

Egress Window appeal attachment!
Cover letter with contact information

Saint Paul City Clerk

310 City Hall, 15 W Kellogg Blvd

Saint Paul, MN 55102

Dear City Clerk,

Please accept this Appeal application regarding an egress window for a rental property at 902 Young Street, St. Paul, MN 55104.

Please send any correspondence regarding this appeal to the contact information below.

Lesley White-Kayser
3910 Longstreet Court
Annandale, VA 22003
703-969-9730
Lwhitekayser@gmail.com

Thank you and have a great day!

Sincerely,
Lesley White-Kayser



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

April 30, 2012

#14 Egress
Window

LESLEY L WHITE
3910 LONGSTREET CT
ANNANDALE VA 22003-1710

FIRE INSPECTION CORRECTION NOTICE

RE: 902 YOUNG ST
Ref. #100880
Residential Class: C

Dear Property Representative:

Your building was inspected on April 30, 2012 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date. **A re-inspection will be made on May 30, 2012 at 2:00 PM.**

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LISTS OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

DEFICIENCY LIST

1. Exterior - Yard - MSFC 307.4.2 Recreational fires shall not be conducted within 25 feet of a structure or combustible material.-Remove the fire pit.
2. Exterior - Roof - NFPA 211,9-2 - Have the chimneys, fireplaces, and vents inspected for soundness, freedom from deposits, and correct clearances. Cleaning, maintenance, and repairs shall be done if indicated by the inspection.-Repair the chimney in an approved manner.

14. Interior Main Level Bedroom - MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651)- 266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information.-Escape window measured 20 and half inches in height by 30 inches in width. Net glazed area measured 23 and a half inches in height by 25 and a half inches in width. Net glazed area is 8.3 square feet.
15. Interior Stairway - Basement - SPLC 34.10 (3), 34.33(2) - Provide an approved handrail. The top of the handrail must be between 34 and 38 inches above the treads and run the entire length of the stair.
16. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.
17. SPLC 39.02(c) - Complete and sign the smoke detector affidavit and return it to this office.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: Sebastian.Migdal@ci.stpaul.mn.us or call me at 651-266-8985 between 8:00 a.m. - 9:30 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Sebastian Migdal
Fire Inspector

Reference Number 100880