✓ Scanned

APPLICATION FOR APPEAL

RECEIVED
MAY 15 2012
CITY CLERK

Saint Paul City Clerk
310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- ☑ $25 filing fee payable to the City of Saint Paul (if cash: receipt number_____)
- ☑ Copy of the City-issued orders or letter which are being appealed
- ☐ Attachments you may wish to include
- ☑ This appeal form completed mailed

YOUR HEARING Date and Time:

Tuesday, 6-5-12

Time 1:30 P.M.

Location of Hearing:
Room 330 City Hall/Courthouse

emailed 5-15-12 jm

Address Being Appealed:

Number & Street: 1239 Scheffer Ave City: St. Paul State: MN Zip: 55116

Appellant/Applicant: Renewal by Andersen Email bryan.horton@andersencorp.com

Phone Numbers: Business 651-264-4088 Residence _____ Cell _____

Signature: _____ Date: _____

Name of Owner (if other than Appellant): John Wilebski

Address (if not Appellant's): 1239 Scheffer Ave

Phone Numbers: Business _____ Residence 651-699-4813 Cell _____

What Is Being appealed and why? *Attachments Are Acceptable*

- ☐ Vacate Order/Condemnation/ Revocation of Fire C of O
- ☐ Summary/Vehicle Abatement
- ☐ Fire C of O Deficiency List
- ☒ [redacted] Only Egress Windows
- ☐ Code Enforcement Correction Notice
- ☐ Vacant Building Registration
- ☐ Other
- ☐ Other
- ☐ Other

We are appealing a basic of 3 replacement windows that will not comply w/ Egress policy. All 3 windows are located in a row which makes alteration difficult. Also changing to different operating style will allow for less clear opening dimensions in width. Homeowner prefers not to change style or configuration.

CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: May 11, 2012

APPEAL PROPERTY ADDRESS: 1239 SCHEFFER AVE

APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION

PHONE NUMBER: 651-264-4914

PERMIT NUMBER: 12 055710

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 1

Total Glazed Area Minimum 5 Square Feet	4.8 sq. ft	**Difference from Required Area**	-2.5 sq. ft.
Width of Opening Minimum 20 Inches	18 3/8"	**Difference from Required Opening**	-1 5/8"
Height of Opening Minimum 24 Inches	18 7/8"	**Difference from Required Opening**	-5 1/8"
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	Ok	**Difference from Maximum Height**	ok

COMMENTS:

Reviewed by: DD 5-11-12