APPLICATION FOR APPEAL

RECEIVED
MAY 16 2012
CITY CLERK

Saint Paul City Clerk
310 City Hall, 15 W. Kellogg Blvd.
Saint Paul, Minnesota 55102
Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- [X] $25 filing fee payable to the City of Saint Paul (if cash: receipt number_____)
- [ ] Copy of the City-issued orders or letter which are being appealed
- [X] Attachments you may wish to include
- [X] This appeal form completed
- [ ] Walk-In *OR* [X] Mail-In

YOUR HEARING Date and Time:
Tuesday, 6-5-12
Time 1:30 P.M.
Location of Hearing:
Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 2184 Larry Ho Drive City: St. Paul State: MN Zip: 55109

Appellant/Applicant: Beissel Window and Siding, Co Email jeff@beisselwindows.com

Phone Numbers: Business 651-451-6835 Residence _____ Cell _____

Signature: Jeff W Beissel Date: 5/15/12

Name of Owner (if other than Appellant): John and Sharon O'Connell

Address (if not Appellant's): 2184 Larry Ho Drive

Phone Numbers: Business _____ Residence 651-738-8310 Cell _____

What Is Being Appealed and Why? *Attachments Are Acceptable*

- [ ] Vacate Order/Condemnation/ Revocation of Fire C of O
- [ ] Summary/Vehicle Abatement
- [ ] Fire C of O Deficiency List
- [ ] Fire C of O: Only Egress Windows
- [ ] Code Enforcement Correction Notice
- [ ] Vacant Building Registration
- [X] Other Bedroom Egress

Revised 3/7/2011

CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: May 11, 2012

APPEAL PROPERTY ADDRESS: 2184 LARRY HO DRIVE

APPLICANT NAME: BEISSEL WINDOW & SIDING CO

PHONE NUMBER: 651-451-6835

PERMIT NUMBER: 12 053554

TYPE OF WINDOW DOUBLE HUNG

NUMBER OF WINDOWS 2

Total Glazed Area Minimum 5 Square Feet	7.75	**Difference from Required Area**	+2.75
Width of Opening Minimum 20 Inches	31 3/8	**Difference from Required Opening**	+11 3/8
Height of Opening Minimum 24 Inches	16 5/8	**Difference from Required Opening**	-7 3/8
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	<48	**Difference from Maximum Height**	OK

COMMENTS:

Reviewed by: R REHN