Scanned

□ Other



# **APPLICATION FOR APPEAL**

# Saint Paul City Clerk

RECEIVED
JUN 1 8 2012

CITY CLERK

310 City Hall, 15 W. Kellogg Blvd. Saint Paul, Minnesota 55102 Telephone: (651) 266-8560

YOUR HEARING Date and Time:  Tuesday, 6-36-12  Time 1:30 fm  Location of Hearing: Room 330 City Hall/Courthouse  Email Late 6-19-12 Jane		
ity: St Paul State: MN Zip: 55/06		
Email Conoryed @ Comeast. Net		
Phone Numbers: Business Residence 651->> 2675 Cell 651-492-6578		
Date: 6-/5-/2		
Address (if not Appellant's): 916 Clavence ST ST Paul MN 55106		
ique as above Cell		
What Is Being Appealed and Why? Attachments Are Acceptable		
opening height of 22"		
T J i cg		



CITY OF SAINT PAUL Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220 Saint Paul, Minnesota 55101-1806 

 Telephone:
 651-266-8989

 Facsimile:
 651-266-8951

 Web:
 www.stpaul.gov/dsi

June 5, 2012

ROSS J CONORYEA RUTH A CONORYEA 916 CLARENCE ST ST PAUL MN 55106-3406

#### FIRE INSPECTION CORRECTION NOTICE

RE:

1364 CASE AVE

Ref. #113501

Residential Class: B

## Dear Property Representative:

Your building was inspected on June 5, 2012 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date. A reinspection will be made on July 6, 2012 at 10:00A.M..

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional reinspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

### **DEFICIENCY LIST**

- 1. SPLC 34.11 (6), 34.34 (3) Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.
- 2. SPLC 39.02(c) Complete and sign the smoke detector affidavit and return it to this office.
- 3. MSFC 605.4 Discontinue use of all multi-plug adapters.-Various locations

- 4. UMC 504.6 Provide, repair or replace the dryer exhaust duct. Exhaust ducts for domestic clothes dryers shall be constructed of metal and shall have a smooth interior finish. The exhaust duct shall be a minimum nominal size of four inches (102 mm) in diameter. This work will require a permit(s). Call DSI at (651) 266-8989.
- 5. MSFC1026.1 Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651)- 266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information.-Double hung windows. Openable height is 22inches. Openable width is 29inches. Sill is 31 inches. Glazed is 46inches in height by 27inches in width.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: http://www.stpaul.gov/cofo

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: james.thomas@ci.stpaul.mn.us or call me at 651-266-8983 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

James Thomas Fire Inspector

Reference Number 113501