

APPLICATION FOR APPEAL

RECEIVED

JUN 1 1 2012

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd. Saint Paul, Minnesota 55102 Telephone: (651) 266-8560

CITY CLERK	
The City Clerk needs the following to process your appeal:	YOUR HEARING Date and Time:
\$25 filing fee payable to the City of Saint Paul	
(if cash: receipt number)	Tuesday, June 26,20
Copy of the City-issued orders or letter which	
are being appealed	Time_\.300.00
Attachments you may wish to include	Location of Hearing:
This appeal form completed	Room 330 City Hall/Courthouse
mailed in	E-Mailed 6-11-12

Address Being Appealed:

Number & Street: 1836 Edgeum	be Rd City: St. Paul State: MN Zip: 55105
Appellant/Applicant: Renewal by	Andersen Email bryan, horton Pandorsencorp. com
Phone Numbers: Business 651-264-4	OBB Residence Cell
Signature:	Date:
Name of Owner (if other than Appellant):	
Address (if not Appellant's): 1236 Ed	grumbe Rd St. Paul MN 55105
Phone Numbers: Business	Residence 1/51-485-5457 Cell
What Is Being appeale	d and why? Attachments Are Acceptable
Vacate Order/Condemnation/ Revocation of Fire C of O	
	& replacement windows will not meet
□ Summary/Vehicle Abatement	2 replacement windows will not meet Egress Policy Sizes attached. Please Approve
□ Fire C of O Deficiency List	
Fire C of O: Only Egress Windows	
Code Enforcement Correction Notice	
□ Vacant Building Registration	
□ Other	
Other	
Other	
	AND A ARROWS CONTRACTOR OF THE PROPERTY OF THE

PHONE: 651-266-8688

651-266-8574

FAX:



CITY OF SAINT PAUL INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK 15 KELLOGG BLVD. WEST 310 CITY HALL SAINT PAUL, MN 55102

DATE: May 30, 2012

APPEAL PROPERTY ADDRESS: 1236 EDGCUMBE ROAD

APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION

PHONE NUMBER: 651-264-4914

PERMIT NUMBER: 12 062223

TYPE OF WINDOW DOUBLE HUNG

NUMBER OF WINDOWS 2

Total Glazed Area	6.9	Difference from Required Area	+1.9
Minimum 5 Square Feet Width of Opening	25	Difference from Required Opening	+5
Minimum 20 Inches			
Height of Opening Minimum 24 Inches	19 7/8	Difference from Required Opening	-4 1/8
Height of Opening to Finished Floor	<48	Difference from Maximum Height	ОК
Maximum 48 Inches for Existing Openings			

COMMENTS: WITH THE INFORMATION PROVIDED ABOVE APPROVAL IS RECOMMENDED.

Reviewed by: REHN