

The City Clerk needs the following to process your appeal:

## APPLICATION FOR APPEAL

JUN 20 2012 **CITY CLERK** 

## Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd. Saint Paul, Minnesota 55102 Telephone: (651) 266-8560

\$25 filing fee payable to the City of (if cash: receipt number)  Copy of the City-issued orders or I are being appealed		YOUR HEARING Date and Time:  Tuesday, 7-10-12	
Attachments you may wish to include:	ude		
This appeal form completed		Time_ 1:30 P.m.	
□ Walk-In OR 🌿 Mail-In		<u>Location of Hearing:</u> Room 330 City Hall/Courthouse	
,		Room 550 City Hath Courthouse	
Address Being Appea		٨	
Number & Street: 00 E	Hawthorne city: St	. Paul	
		nail Joann. Donby a Toro. (	'0m
Phone Numbers: Business 95 3 887	-8087 Residence	NONE Cell 612 381-6306	>
Signature: DONO	Ly	Date:	
Name of Owner (if other than Appellant	·):		
Address (if not Appellant's):			
Phone Numbers: Business	Residence	Cell	
What Is Being Appeal	led and Why?	Attachments Are Acceptable	
Vacate Order/Condemnation/ Revocation of Fire C of O			
□ Summary/Vehicle Abatement			1 Her
Fire C of O Deficiency List	# 1 - they are the		yyho Y
☐ Fire C of O: Only Egress Windows	- The case	my Cha	Jose (
□ Code Enforcement Correction Notice	3	Lo Bros	1 km
□ Vacant Building Registration		family	ひナ
□ Other		767-5	yis .
45 Nord time 1	h al santors	Revised 3/7/2011	G



CITY OF SAINT PAUL Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220 Saint Paul, Minnesota 55101-1806

651-266-8989 Telephone: Facsimile: 651-266-8951

Web: www.stpaul.gov/dsi

June 12, 2012

JOANN DONLEY 561 SPRUCE ST EAGAN MN 55123-4910

## FIRE INSPECTION CORRECTION NOTICE

RE:

2010 HAWTHORNE AVE E

Ref. #114375

Residential Class: C

Dear Property Representative:

Your building was inspected on June 12, 2012 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date. A reinspection will be made on July 12, 2012 at 12:30P.M..

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional reinspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

## **DEFICIENCY LIST**



All Bedrooms - MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651)- 266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information.-Doouble hung windows. Openable height is 20inches. Openable width is 25inches. Sill 28inches. Glazed is 44inches in height by 22inches in width.

Attic - MN Stat. 299F.362 - Immediately provide and maintain a smoke detector located 2. outside each sleeping area.

An Equal Opportunity Employer

- Attic MN State Statute 299F.50 Immediately provide and maintain an approved Carbon 3. Monoxide Alarm in a location within ten (10) feet of each sleeping area. Installation shall be in accordance with manufacturers instructions.
- Basement MSFC 605.1- All light fixtures shall be maintained with protective globes if originally equipped.
  - Garage SPLC 34.08 (5), 34.31 (3) Repair, replace and maintain all exterior surfaces on fences, sheds, garages and other accessory structures free from holes and deterioration. Provide and maintain exterior unprotected surfaces painted or protected from the elements.
- Various locations MSFC 605.4 Discontinue use of all multi-plug adapters. 6.
- Various locations MSFC 605.5 Discontinue use of extension cords used in lieu of 7. permanent wiring.
- basement MSFC 605.6 Provide electrical cover plates to all outlets, switches and 8. junction boxes where missing.
- SPLC 34.11 (6), 34.34 (3) Provide service of heating facility by a licensed contractor 9. which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.
- SPLC 39.02(c) Complete and sign the smoke detector affidavit and return it to this 10. office.
- SPLC 34.09 (3), 34.32 (3) Provide or repair and maintain the window screen. 11.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: http://www.stpaul.gov/cofo

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: james.thomas@ci.stpaul.mn.us or call me at 651-266-8983 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

James Thomas Fire Inspector

Reference Number 114375

www St Paul. Gov Gov Pitu Clerk

266-8989