



APPLICATION FOR APPEAL

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

RECEIVED

JUL 10 2012

CITY CLERK

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed
- Walk-In OR Mail-In

YOUR HEARING Date and Time:

Tuesday, July 24, 2012

Time 1:30 P.M.

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 1237 7th St E City: St Paul State: MN Zip: 55104

Appellant/Applicant: Tom Gergen / Ryan Whissler / Douglas Email _____

Phone Numbers: Business _____ Residence _____ Cell 6512710601

Signature: [Signature] Date: _____

Name of Owner (if other than Appellant): TR Group LLC / Ryan Whissler

Address (if not Appellant's): _____

Phone Numbers: Business _____ Residence _____ Cell 6512710601

What Is Being Appealed and Why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other

#6 on fire CoFO

Window sizes are big enough but fire Marshall Inspector told us it would pass on appeal.



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

June 28, 2012

TR GROUP LLC
2038 Ford Pky Ste 333
Saint Paul MN 55116-1931

FIRE INSPECTION CORRECTION NOTICE

RE: 1237 7TH ST E
Ref. #106444
Residential Class: A

Dear Property Representative:

Your building was inspected on June 28, 2012 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date. A re-inspection will be made on July 26, 2012 at 10:00 a.m.

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

DEFICIENCY LIST

1. Basement - lower unit stairs - SPLC 34.10 (3), 34.33(2) - Provide an approved handrail. The top of the handrail must be between 34 and 38 inches above the treads and run the entire length of the stair.
2. Basement - upper unit panel - NEC 230-2 (e) - Provide identification at the service disconnect for each electrical circuit.-Label the circuits in the panel box.

3. Garage - SPLC 34.08 (5), 34.31 (3) - Repair, replace and maintain all exterior surfaces on fences, sheds, garages and other accessory structures free from holes and deterioration. Provide and maintain exterior unprotected surfaces painted or protected from the elements.-Vent missing, open hole. Overhead door not secure.
4. Garage - SPLC 34.10 (3), 34.33(2) - Repair or replace the unsafe stairway in an approved manner.-Provide a code compliant step for the interior of the garage at the side door.
5. Upper unit - Multiple locations - MSFC 605.5 - Discontinue use of extension cords used in lieu of permanent wiring.
6. Windows - MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651)-266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information.-
Upper Unit Front: Double hung, 28h x 16.5w
Upper Unit Rear: Remove the A/C unit from the egress window
Lower Unit Front: Size meets requirements, but goes into an enclosed porch.
7. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.
8. SPLC 39.02(c) - Complete and sign the smoke detector affidavit and return it to this office.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: leanna.shaff@ci.stpaul.mn.us or call me at 651-266-8980 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Leanna Shaff
Fire Inspector

Reference Number 106444