

Vang, Mai (CI-StPaul)

From: Imbertson, Mitchell (CI-StPaul)
Sent: Thursday, December 20, 2012 2:02 PM
To: Neis, Adrian (CI-StPaul); Vang, Mai (CI-StPaul)
Cc: Wiese, Angie (CI-StPaul)
Subject: RE: 1966 Benson Ave. - Appeal

All-

Here's what I've found so far. I have scanned a number of old inspection reports which reference this, these will be uploaded to a condition folder shortly.

-During a number of inspections and re-inspections during 1997, 98 and 99, deficiencies were noted for storage exceeding 12 ft high. These orders were checked off on but there weren't any notes or records to suggest that any appeals were filed.

-Also included in the condition folder is a letter from Paul Amidon (Amidon Graphics President) dated 7-23-97. This letter states that they are unable to comply with the limits for height of paper storage because they were out of space in the building. He requested an extension until 10-20-97 when a new building would be completed to expand into. There was no mention of any attempt to obtain a variance for permanent increase in height.

-In more recent inspections I didn't see any other occasions where they were cited for exceeding 12' and didn't see any reference to variances or appeal.

Mitch

From: Neis, Adrian (CI-StPaul)
Sent: Tuesday, December 18, 2012 1:52 PM
To: Imbertson, Mitchell (CI-StPaul)
Cc: Wiese, Angie (CI-StPaul)
Subject: 1966 Benson Ave. - Appeal

Owner will take additional photographs of the paper storage and submit them to LHO.

Mitch look into the paper file to see if there is a variance already on file. The owner believes there already is. If so, let LHO know so it is on file.

They are requesting variance of 4 foot floor required for dense rolled paper storage. All rack storage can be maintained under 12 feet. They indicate there are 20 foot ceilings.

Laid over until January 15th.

AJ.