

We need the following to process your appeal:

## APPLICATION FOR APPEAL

# Saint Paul City Council - Legislative Hearings

JUN 06 2013 CITY CLERK 310 City Hall, 15 W. Kellogg Blvd. Saint Paul, Minnesota 55102 Telephone: (651) 266-8585

\$25 filing fee payable to the City of Saint Paul	HEARING DATE & TIME
(if cash: receipt number waived)	(provided by Legislative Hearing Office)
Copy of the City-issued orders/letter being appealed	Tuesday, June 7, 2013
Attachments you may wish to include	
★ This appeal form completed	Time 2:00 p.m.
Walk-In OR   Mail-In	Location of Hearing:
	Room 330 City Hall/Courthouse
for abatement orders only:     Email OR   Fax	
Address Being Appealed:	
Number & Street: 16 60 Cumber phl City: 57. Paul State: MP Zip: 55/12	
Appellant/Applicant: DAVE Pagh Email	
Phone Numbers: Business 651-644-05/ = Residence Cell	
Signature: Date: 6-6-13	
Name of Owner (if other than Appellant):	
Mailing Address if Not Appellant's:	
Phone Numbers: Business Residence	Cell
What Is Being Appealed and Why? Attachments Are Acceptable	
Vacate Order/Condemnation/ Revocation of Fire C of O	more time
□ Summary/Vehicle Abatement + 12 De	able to move
□ Fire C of O Deficiency List	10 1000
Code Enforcement Correction Notice	
□ Vacant Building Registration	
□ Other	



CITY OF SAINT PAUL Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220 Saint Paul, Minnesota 55101-1806 Telephone: 651-266-8989 Facsimile: 651-266-8951 Web: www.stpaul.gov/dsi

May 31, 2013

PRC HOMES LLC PEGGY CHUN 1043 GRAND AVE APT 309 ST PAUL MN 55105

### Revocation of Fire Certificate of Occupancy and Order to Vacate

RE:

1660 CUMBERLAND ST

Ref. # 15857

Dear Property Representative:

Your building was inspected on May 29, 2013, for the renewal of the Certificate of Occupancy. Since you have failed to comply with the applicable requirements, it has become necessary to revoke the Certificate of Occupancy in accordance with Section 40.06 of the Saint Paul Legislative Code.

### A re-inspection will be made on or after June 28, 2013 or the property vacated.

The Saint Paul Legislative Code further provides that no building shall be occupied without a Certificate of Occupancy. Failure to immediately complete the following deficiency list or the building vacated may result in a criminal citation.

#### DEFICIENCY LIST

1. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.
Contact a licensed mechanical contractor to repair/replace all inoperable zone valves and provide documentation that all zone valves are operable.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: http://www.stpaul.gov/cofo.

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: wayne.spiering@ci.stpaul.mn.us or call me at 651-266-8993 between 7:30 - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Wayne Spiering Fire Inspector

Ref. # 15857