



# APPLICATION FOR APPEAL

## Saint Paul City Council – Legislative Hearings

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8585

June 18, 2013

### We need the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number 351957)
  - Copy of the City-issued orders/letter being appealed
  - Attachments you may wish to include
  - This appeal form completed
  - Walk-In OR  Mail-In
- for abatement orders only:  Email OR  Fax

<b>HEARING DATE &amp; TIME</b> (provided by Legislative Hearing Office) Tuesday, <u>June 18, 2013</u>
Time <u>11:30 a.m.</u>
Location of Hearing: Room 330 City Hall/Courthouse

### Address Being Appealed:

Number & Street: 1660 Cumberland St City: St Paul State: MN Zip: 55117

Appellant/Applicant: PEGGY CHUN Email: pelimar@msn.com

Phone Numbers: Business \_\_\_\_\_ Residence \_\_\_\_\_ Cell 651-755-5573

Signature: [Signature] Date: 6/14/13

Name of Owner (if other than Appellant): \_\_\_\_\_

Mailing Address if Not Appellant's: 1043 Grand Ave #309 St. Paul MN 55105

Phone Numbers: Business \_\_\_\_\_ Residence \_\_\_\_\_ Cell \_\_\_\_\_

Not reasonable to revoke Cof O for add'l boiler items when it is off + safety test was completed  
**What Is Being Appealed and Why?** Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other

March 28 letter stated extension to 5/1/13

May 1st - Heating Test Completed

May 7th - added AC + Patio Door to list

May 14th Cof O Revoked All items done waiting for Insp

31, May 23 States Revoked Building Insp to sign off

only for boiler test

test passed + submitted 5/24/13

\* Boiler off for season. Cof O should have been reinstated



CITY OF SAINT PAUL  
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220  
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989  
Facsimile: 651-266-8951  
Web: [www.stpaul.gov/dsi](http://www.stpaul.gov/dsi)

March 28, 2013

PRC HOMES LLC  
PEGGY CHUN  
1043 GRAND AVE APT 309  
ST PAUL MN 55105

RE: RE-INSPECTION FIRE CERTIFICATE OF OCCUPANCY WITH DEFICIENCIES  
1660 CUMBERLAND ST

Ref. # 15857

Dear Property Representative:

Your building was re-inspected for the Fire Certificate of Occupancy on March 21, 2013. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected immediately.

**A FINAL re-inspection will be made on May 2, 2013 at 9:30am. Failure to comply will result in enforcement action.**

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

#### DEFICIENCY LIST

1. 206 - Living Room - SPLC 34.12 (2), 34.35 (1) - Repair and maintain all required and supplied equipment in an operative and safe condition.-Repair/replace the inoperable A/C unit.

**Note: Inspector will grant an extension until May 1, 2013 to come into compliance.**

2. 301 - Northwest Bedroom - SPLC 34.10 (7), 34.33 (6) - Repair and maintain the ceiling in an approved manner.

**Note: Inspector will grant an extension until May 1, 2013 to come into compliance.**

3. Exterior - Roof - SPLC 34.09 (1) e, 34.32 (1) d - Provide and maintained the roof weather tight and free from defects.-Repair/replace the damaged/leaking roof. This work must be done under permit and approved by area building inspector.

**Note: Inspector has accepted the plan of action submitted by Jose Verdeja and granted an extension until May 1, 2013 to come into compliance.**

4. Exterior - Window Frames - SPLC 34.09 (3), 34.32 (3) - Repair and maintain the window frame.-Replace all rotted/deteriorated window frames. Maintain all exterior wood surfaces protected against elements of the weather. This work must be done under permit.

**Note: Inspector has accepted the plan of action submitted by Jose Verdeja and granted an extension until May 1, 2013 to come into compliance.**

5. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.-The submitted Existing Fuel Burning Equipment Safety Test Report has been completed by Tim's Quality Plumbing. Tim's Quality Plumbing is not licensed in the City of St Paul to perform this inspection/test. Contact a licensed contractor to provide service of heating facility and complete the Existing Fuel Burning Equipment Safety Test Report.

**Note: Inspector will grant an extension until May 1, 2013 to come into compliance.**

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>.

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of the original orders.

If you have any questions, email me at [wayne.spiering@ci.stpaul.mn.us](mailto:wayne.spiering@ci.stpaul.mn.us) or call me at 651-266-8993 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Wayne Spiering  
Fire Inspector  
Ref. # 15857



# EXISTING FUEL BURNING EQUIPMENT SAFETY TEST REPORT

(Use separate form for each Appliance)

Department of Safety & Inspections  
Fire Prevention Division  
375 Jackson Street - Suite 220  
Saint Paul MN 55101  
Fax: 651-266-8951

Address: 1660 Cumberland St. Date: 5/1/03

Owner: PRC Homes LP (contact Peggy)

### Type of Heat:

Gravity Air \_\_\_\_\_ Forced Air \_\_\_\_\_ Gravity Hot Water \_\_\_\_\_ Forced Hot Water X  
Steam \_\_\_\_\_ Unit Heater \_\_\_\_\_ Space Heater \_\_\_\_\_ Other \_\_\_\_\_

Type of Fuel: Gas X Oil \_\_\_\_\_ Other \_\_\_\_\_

Gas Design \_\_\_\_\_ Conversion \_\_\_\_\_

Make of Burner Hydro Therm Make \_\_\_\_\_

Model no name plate Model \_\_\_\_\_

Serial no name plate Max. BTU Rating \_\_\_\_\_

Input no name plate Make of Furnace \_\_\_\_\_

Equipment venting type: Atmospheric X Induced Fan \_\_\_\_\_ Other \_\_\_\_\_

Total BTU input of all vented gas appliances per chimney: Boiler Plus 120,000

Type of Chimney: Masonry X Class B \_\_\_\_\_ Other \_\_\_\_\_

Type of Liner: None \_\_\_\_\_ Metal \_\_\_\_\_ Clay Tile X

Combustible Air Supply Required?: Yes X No \_\_\_\_\_ Installed?: Yes X No \_\_\_\_\_

### Safety & Operating Control Tests:

	Yes	No	Fuel Analysis/Flue Gas Analysis:	Yes	No
Pilot/Flame Safeguard Operating Properly	<u>X</u>	_____	Vents Properly without Spillage	<u>X</u>	_____
Limit(s) Operating Properly	<u>X</u>	_____	Flame Stays Inside/Doesn't Roll Out	<u>X</u>	_____
Operator(s) Operating Properly	<u>X</u>	_____	Burner Lights Smoothly	<u>X</u>	_____
Low Water Cut-Off Operating Properly	<u>N/A</u>	_____			
All Controls Operating Properly	_____	_____			

	Initial	Final	Visual Inspection	Yes	No
Stack Temperature	<u>570</u> F/Net	<u>606</u> F/Net	Fuel Piping System - Okay	<u>X</u>	_____
Oxygen	<u>8.4</u> %	<u>9.2</u> %	Vent Systems - Draft Hood, Connector, Vent Chimney - Okay	<u>X</u>	_____
Carbon Dioxide	<u>7.1</u> %	<u>6.56</u> %			
Carbon Monoxide	<u>38</u> % / ppm	<u>40</u> % / ppm	Heating Unit - Okay	<u>X</u>	_____

Carbon Monoxide Detector (tube type) Positive \_\_\_\_\_ Negative \_\_\_\_\_

### Look At Total Heating System Before You Leave:

Does system operate safely and properly? Yes X No \_\_\_\_\_

COMMENTS: would like boiler cleaned (this summer) fire side

Name of Licensed Contractor: MH Mech Inc Address 23996 Olundale Phone # 651-248-5795

Person Doing Test (Print) Mike Kuster (signature) Mike Kuster

Certificate of Competency Number from City of Saint Paul for Appropriate Fuel: 20040000723

1660 Cumberland

testo 327-1  
 V1.07 01573210/USA  
 04/29/2013 05:14:55  
 Fuel Nat Gas  
 CO2 max 11.7 %

*Left* Flue gas  
 9.2 % Oxygen  
 6.56 % CO2  
 40 ppm CO  
 606.6 °F T stack  
 75.0 % EFF  
 121.6 °F Dewpoint  
 66 ppm CO AirFree  
 71.6 °F Ambient temp  
 71.1 % ExAIR  
 76.8 °F Instrum temp  
 --- °F T1 temp.  
 --- °F T2 temp.  
 --- °F Diff. temp.  
 --- inH2O Diff. Press  
 --- inH2O Draft

testo 327-1  
 V1.07 01573210/USA  
 04/29/2013 05:10:37  
 Fuel Nat Gas  
 CO2 max 11.7 %

*Rt* Flue gas  
 8.4 % Oxygen  
 7.01 % CO2  
 38 ppm CO  
 570.0 °F T stack  
 77.0 % EFF  
 123.4 °F Dewpoint  
 64 ppm CO AirFree  
 71.2 °F Ambient temp  
 60.8 % ExAIR  
 77.0 °F Instrum temp  
 --- °F T1 temp.  
 --- °F T2 temp.  
 --- °F Diff. temp.  
 --- inH2O Diff. Press  
 --- inH2O Draft



CITY OF SAINT PAUL  
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220  
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989  
Facsimile: 651-266-8951  
Web: [www.stpaul.gov/dsi](http://www.stpaul.gov/dsi)

May 7, 2013

PRC HOMES LLC/PEGGY CHUN  
1043 GRAND AVE APT 309  
ST PAUL MN 55105

RE: RE-INSPECTION FIRE CERTIFICATE OF OCCUPANCY WITH DEFICIENCIES  
1660 CUMBERLAND ST

Ref. # 15857

Dear Property Representative:

Your building was re-inspected for the Fire Certificate of Occupancy on May 3, 2013. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected immediately.

**A FINAL re-inspection will be made on May 10, 2013 at 1:00pm. Failure to have all items completed will result in enforcement action.**

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

#### DEFICIENCY LIST

1. 206 - Living Room - SPLC 34.12 (2), 34.35 (1) - Repair and maintain all required and supplied equipment in an operative and safe condition. **-Repair/replace the inoperable A/C unit.**
2. 206 - Patio Door - Ext. Door SPLC 34.09 (3), 34.33 (3) - Repair and maintain the door in good condition. **-Repair/replace the sliding patio door that is coming out of the track when it is opened.**
3. Exterior - Roof - SPLC 34.09 (1) e, 34.32 (1) d - Provide and maintained the roof weather tight and free from defects. **-Repair/replace the damaged/leaking roof. This work must be done under permit and approved by area building inspector.**

**Note: There is an open building permit. Contact building inspector, Virgil Thomas 651-266-9023, for final inspection.**

*New Items Requested Building WSP to Come. Not Available*

4. Exterior - Window Frames - SPLC 34.09 (3), 34.32 (3) - Repair and maintain the window frame.-Replace all rotted/deteriorated window frames. Maintain all exterior wood surfaces protected against elements of the weather. This work must be done under permit.

**Note: There is an open building permit. Contact building inspector, Virgil Thomas 651-266-9023, for final inspection.**

- Done  
May 1st*
5. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.-**The submitted Existing Fuel Burning Equipment Safety Test Report has been completed by MK Mechanical, Inc. The stack temps on each boiler are outside the acceptable range, there is a bad ambient lockout, zone valves need to be replaced, boiler pumps are inoperable, and the burners need to be cleaned. Contact a licensed mechanical contractor to repair/replace the boilers under permit and then complete/submit another Existing Fuel Burning Equipment Safety Test report.**

*↑ These were recommended for Fall before heating season starts*

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>.

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of the original orders.

If you have any questions, email me at [wayne.spiering@ci.stpaul.mn.us](mailto:wayne.spiering@ci.stpaul.mn.us) or call me at 651-266-8993 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Wayne Spiering  
Fire Inspector  
Ref. # 15857



CITY OF SAINT PAUL  
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220  
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989  
Facsimile: 651-266-8951  
Web: [www.stpaul.gov/dsi](http://www.stpaul.gov/dsi)

May 14, 2013

PRC HOMES LLC  
PEGGY CHUN  
1043 GRAND AVE APT 309  
ST PAUL MN 55105

### Revocation of Fire Certificate of Occupancy and Order to Vacate

RE: 1660 CUMBERLAND ST  
Ref. # 15857

Dear Property Representative:

Your building was inspected on May 10, 2013, for the renewal of the Certificate of Occupancy. Since you have failed to comply with the applicable requirements, it has become necessary to revoke the Certificate of Occupancy in accordance with Section 40.06 of the Saint Paul Legislative Code.

**A re-inspection will be made on May 29, 2013 at 12:30pm or the property vacated.**

The Saint Paul Legislative Code further provides that no building shall be occupied without a Certificate of Occupancy. Failure to immediately complete the following deficiency list or the building vacated may result in a criminal citation.

#### DEFICIENCY LIST

1. 206 - Living Room - SPLC 34.12 (2), 34.35 (1) - Repair and maintain all required and supplied equipment in an operative and safe condition. **-Repair/replace the inoperable A/C unit.**

Exterior - Roof - SPLC 34.09 (1) e, 34.32 (1) d - Provide and maintained the roof weather tight and free from defects. **-Repair/replace the damaged/leaking roof.** This work must be done under permit and approved by area building inspector.

**Note: There is an open building permit. Contact building inspector, Virgil Thomas 651-266-9023, for final inspection.**

*Blew cold*  
*Requesting*  
*He said Virgil*  
*not satisfied*  
*until*  
*5/29/13*



3. Exterior - Window Frames - SPLC 34.09 (3), 34.32 (3) - Repair and maintain the window frame.-Replace all rotted/deteriorated window frames. Maintain all exterior wood surfaces protected against elements of the weather. This work must be done under permit.

**Note: There is an open building permit. Contact building inspector, Virgil Thomas 651-266-9023, for final inspection.**

4. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.-**The submitted Existing Fuel Burning Equipment Safety Test Report has been completed by MK Mechanical, Inc. The stack temps on each boiler are outside the acceptable range, there is a bad ambient lockout, zone valves need to be replaced, boiler pumps are inoperable, and the burners need to be cleaned. Contact a licensed mechanical contractor to repair/replace the boilers under permit and then complete/submit another Existing Fuel Burning Equipment Safety Test report.**

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>.

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: [wayne.spiering@ci.stpaul.mn.us](mailto:wayne.spiering@ci.stpaul.mn.us) or call me at 651-266-8993 between 7:30 - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Wayne Spiering  
Fire Inspector

Ref. # 15857

It was still snowing in May. We needed to turn off boiler to clean out. Done & passed again on 5/24/13

Done  
Boiler  
off



# EXISTING FUEL BURNING EQUIPMENT SAFETY TEST REPORT

(Use separate form for each Appliance)

Department of Safety & Inspections  
Fire Prevention Division  
375 Jackson Street - Suite 220  
Saint Paul MN 55101  
Fax: 651-266-8951

Address: 1660 Cumberland ST.

Date: 5/24/13

Owner: PRC Homes LP

**Type of Heat:**

Gravity Air \_\_\_\_\_ Forced Air \_\_\_\_\_ Gravity Hot Water \_\_\_\_\_ Forced Hot Water X  
Steam \_\_\_\_\_ Unit Heater \_\_\_\_\_ Space Heater \_\_\_\_\_ Other \_\_\_\_\_

Type of Fuel: Gas X Oil \_\_\_\_\_ Other \_\_\_\_\_

**Gas Design**

Make of Burner HydroTherm  
Model HR 1000 HATE  
Serial 01 1  
Input 11 1

**Conversion**

Make \_\_\_\_\_  
Model \_\_\_\_\_  
Max. BTU Rating \_\_\_\_\_  
Make of Furnace \_\_\_\_\_

Equipment venting type: Atmospheric X Induced Fan \_\_\_\_\_ Other \_\_\_\_\_

**Total BTU input of all vented gas appliances per chimney:**

Type of Chimney: Masonry X Class B \_\_\_\_\_ Other 120,000

Type of Liner: None \_\_\_\_\_ Metal \_\_\_\_\_ Clay Tile X

Combustible Air Supply Required?: Yes X No \_\_\_\_\_ Installed?: Yes X No \_\_\_\_\_

**Safety & Operating Control Tests:**

	<b>Yes</b>	<b>No</b>
Pilot/Flame Safeguard Operating Properly	<u>X</u>	_____
Limit(s) Operating Properly	<u>X</u>	_____
Operator(s) Operating Properly	<u>X</u>	_____
Low Water Cut-Off Operating Properly	<u>N/A</u>	_____
All Controls Operating Properly	_____	_____

**Fuel Analysis/Flue Gas Analysis:**

	<b>Yes</b>	<b>No</b>
Vents Properly without Spillage	<u>X</u>	_____
Flame Stays Inside/Doesn't Roll Out	<u>X</u>	_____
Burner Lights Smoothly	<u>X</u>	_____

	<b>Initial</b>	<b>Final</b>
Stack Temperature	<u>453</u> F/Net	<u>501</u> F/Net
Oxygen	<u>11</u> %	<u>11.3</u> %
Carbon Dioxide	<u>5.6</u> %	<u>5.4</u> %
Carbon Monoxide	<u>44</u> % / ppm	<u>34</u> % / ppm

**Visual Inspection**

	<b>Yes</b>	<b>No</b>
Fuel Piping System - Okay	<u>X</u>	_____
Vent Systems - Draft Hood, Connector, Vent Chimney - Okay	<u>X</u>	_____
Heating Unit - Okay	<u>X</u>	_____

Carbon Monoxide Detector (tube type) Positive ~~Negative~~

**Look At Total Heating System Before You Leave:**

Does system operate safely and properly? Yes 0 No \_\_\_\_\_

COMMENTS: Tested after clean \*

Name of Licensed Contractor: M H Mech Inc Address 23996 Okanagon Phone # 651-248-5795

Person Doing Test (Print) Mike Koster (signature) Mike Koster

Certificate of Competency Number from City of Saint Paul for Appropriate Fuel: 20040000723

*Had to disassemble boiler to clean. waitd for it to be turned off. snow in May*

testo 327-1  
V1.07 01573210/USA

05/22/2013 #1 03:17:28

Fuel Nat Gas  
CO2 max 11.7 %

Flue gas

11.0 % Oxygen  
5.56 % CO2  
53.41 ppm CO  
53.3 °F T stack  
74.8 °F EFF  
117.1 °F Dewpoint  
90 ppm CO Airfree  
76.6 °F Ambient temp  
326.3 °F EXAIR  
72.9 °F Instrum temp  
--- °F T1 temp.  
--- °F T2 temp.  
--- °F Diff. temp.  
--- inH2O Diff. Press  
--- inH2O Draft

testo 327-1  
V1.07 01573210/USA

05/22/2013 #2 03:12:51

Fuel Nat Gas  
CO2 max 11.7 %

Flue gas

11.0 % Oxygen  
5.56 % CO2  
53.41 ppm CO  
53.3 °F T stack  
74.8 °F EFF  
117.1 °F Dewpoint  
90 ppm CO Airfree  
76.6 °F Ambient temp  
326.3 °F EXAIR  
72.9 °F Instrum temp  
--- °F T1 temp.  
--- °F T2 temp.  
--- °F Diff. temp.  
--- inH2O Diff. Press  
--- inH2O Draft



CITY OF SAINT PAUL  
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220  
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989  
Facsimile: 651-266-8951  
Web: [www.stpaul.gov/dsi](http://www.stpaul.gov/dsi)

May 31, 2013

PRC HOMES LLC  
PEGGY CHUN  
1043 GRAND AVE APT 309  
ST PAUL MN 55105

### Revocation of Fire Certificate of Occupancy and Order to Vacate

RE: 1660 CUMBERLAND ST  
Ref. # 15857

Dear Property Representative:

Your building was inspected on May 29, 2013, for the renewal of the Certificate of Occupancy. Since you have failed to comply with the applicable requirements, it has become necessary to revoke the Certificate of Occupancy in accordance with Section 40.06 of the Saint Paul Legislative Code.

*Only valves  
zone remained.*

**A re-inspection will be made on or after June 28, 2013 or the property vacated.**

The Saint Paul Legislative Code further provides that no building shall be occupied without a Certificate of Occupancy. Failure to immediately complete the following deficiency list or the building vacated may result in a criminal citation.

#### DEFICIENCY LIST

1. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.- **Contact a licensed mechanical contractor to repair/replace all inoperable zone valves and provide documentation that all zone valves are operable.**

*Passed  
insp  
Done  
5/24/13*

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>.

*Zone valves done on 6/5/13  
Not required for C of O when  
test passed, boiler off for season.*

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: [wayne.spiering@ci.stpaul.mn.us](mailto:wayne.spiering@ci.stpaul.mn.us) or call me at 651-266-8993 between 7:30 - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Wayne Spiering  
Fire Inspector

Ref. # 15857



**STATE SUPPLY COMPANY, INC.**

597 Seventh Street East  
 Saint Paul, MN 55130-2419  
 Phone: 651-774-5985  
 Fax: 651-774-7156

**PICK TICKET**  
 REPRINT

Number	403249
Date	06/05/2013
Page	1

<b>Ship To:</b> 001	ELT Minneapolis LLC 4800 East River Road Door 87 Minneapolis, MN 55421	<b>Bill To:</b> 36238	ELT Minneapolis LLC Door 87 4850 East River Rd Fridley, MN 55421	3:57 pm
------------------------	---	--------------------------	---	---------

P.O. Number	Ordered	Requested	Sisp	Terms	Wh	Freight	Ship Via
Dan	06/05/13	ASAP	11C	NET 30	01	PRE/ADD	WC

Item	Description	Ordered	Ship	Back	UM	On Hand	Loc
HN1090	HNWC 40003916-021 POWER- HEAD 24VOLT OLD 130441ANA  M/C 5347-3300-0003-9414 EXP 01/14 V862 PEGGY 651-755-5573  STATE SUPPLY 597 7TH STREET E SAINT PAUL, MN 55130  06/05/2013 16:57:09 Merchant ID: 00000001862464 Terminal ID: 02786495 226451238993  CREDIT CARD MC ADJUST SALE  CARD # XXXXXXXXXXXX9414 INVOICE 0010 Batch #: 000626 Approval Code: 558956 Entry Method: Manual Mode: Online Tax Amount: \$25.51 Avs Code: NNN Card Code: M  SALE AMOUNT \$360.16  CUSTOMER COPY	5	5		EA	10	2 11 A

Requested by Dan Taken by MRC	W197	<b>Total Weight:</b>	15.0
-------------------------------	------	----------------------	------