



APPLICATION FOR APPEAL

Saint Paul City Council – Legislative Hearings
RECEIVED

AUG 08 2013

CITY CLERK

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8585

We need the following to process your appeal:

- ☒ \$25 filing fee payable to the City of Saint Paul
(if cash: receipt number _____)
- ☒ Copy of the City-issued orders/letter being appealed
- ☐ Attachments you may wish to include
- ☒ This appeal form completed
- ☐ Walk-In OR ☒ Mail-In

for abatement orders only: ☐ Email OR ☐ Fax

HEARING DATE & TIME

(provided by Legislative Hearing Office)

Tuesday, August 20, 2013

Time 1:30 p.m.

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 2174 Reaney Ave City: St. Paul State: MN Zip: 55119

Appellant/Applicant: Patti M. Cournoyer Email PattiCakes1224@aol.

Phone Numbers: Business 651-770-2582 Residence 651-770-2582 Cell 651-434-7870

Signature: Patti M. Cournoyer Date: 8- -13

Name of Owner (if other than Appellant): _____

Mailing Address  **Patti's Daycare**
2076 Larpenleur Ave. E.
St. Paul, MN 55109

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being Appealed and Why? Attachments Are Acceptable

- ☐ Vacate Order/Condemnation/
- ☐ Revocation of Fire C of O
- ☐ Summary/Vehicle Abatement
- ☒ Fire C of O Deficiency List
- ☐ Code Enforcement Correction Notice
- ☐ Vacant Building Registration
- ☐ Other _____

windows



CITY OF SAINT PAUL

Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220 Telephone: 651-266-8989
Saint Paul, MN 55101-1806 Fax: 651-266-8951

July 5, 2013

PATTI COURNOYER
2076 LARPENTEUR AVE E
ST PAUL MN 55119

CORRECTION NOTICE - DAYCARE INSPECTION

RE: 2176 REANEY AVE

Dear Property Representative:

A re-inspection was made on your building on July 5, 2013, in response to a referral. You are hereby notified that the following deficiencies must be corrected immediately. **A re-inspection will be made on or after July 22, 2013.**

Failure to comply may result in a criminal citation or the revocation of the Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

DEFICIENCY LIST

1. BEDROOM WINDOWS - OPENABLE HEIGHT AND WIDTH - MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651) - 266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information.-The openable dimensions of the two main level bedrooms are as follows. Both east and west bedrooms have 2 original existing windows each. Openable height for all windows is 18 inches high. Openable width for all windows is 28 inches wide.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

If you have any questions, email me at james.perucca@ci.stpaul.mn.us or call me at 651-266-8996 between 7:30 a.m - 9:00 a.m.

Please help to make Saint Paul a safer city in which to live and work.

Sincerely,

James Perucca
Fire Inspector