



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

February 28, 2013

STEVEN FLANDERS
DONNASUE FLANDERS
705 EDMUND AVE
ST PAUL MN 55104-2727

Revocation of Fire Certificate of Occupancy

RE: 707 EDMUND AVE

Dear Property Representative:

Your building was determined to be a registered vacant building on February 28, 2013. Since certificates are for the occupancy of buildings, it has become necessary to revoke the Certificate of Occupancy.

Saint Paul Legislative Code provides that no building shall be occupied without a Certificate of Occupancy. In order to re-occupy the building, the following deficiencies (if applicable) must be corrected and **a complete Certificate of Occupancy inspection will be required.**

DEFICIENCY LIST

1. Basement - MSFC 315.2.5 - Fueled equipment, including but not limited to motorcycles, mopeds, lawn-care equipment and portable cooking equipment, shall not be stored, operator or repaired within a building.
2. Exterior - SPLC 34.09 (1) b,c, 34.32 (1) b,c - Provide and maintain all exterior walls free from holes and deterioration. All wood exterior unprotected surfaces must be painted or protected from the elements and maintained in a professional manner free from chipped or peeling paint.
3. Exterior - SPLC 34.09 (2), 34.32(2) - Repair or replace the unsafe stairways, porch, decks or railings in an approved manner. This work may require a permit(s). Call DSI at (651) 266-9090.
4. Interior - SPLC 34.10 (7), 34.33 (6) - Repair and maintain the walls in an approved manner.

5. Interior - SPLC 34.10 (7), 34.33 (6) - Repair and maintain the floor in an approved manner.
6. Interior - SPLC 34.10 (7), 34.33 (6) - Repair and maintain the cabinets in an approved manner.
7. Interior - SPLC 34.09 (3), 34.32 (3) - Repair and maintain the door in good condition.
8. Interior - SPLC 34.11 (4), 34.34 (1), MPC 4515, MPC 326 - Connect or cap the sewer piping in accordance with the plumbing code. The bathroom sinks have been relocated. This work requires a permit. Contact DSI at 651-266-8989.-Obtain approval under permit.
9. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit an approved completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.
10. SPLC 39.02(c) - Complete and sign the smoke detector affidavit and return it to this office.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: william.beumer@ci.stpaul.mn.us or call me at 651-266-8991 between 7:30 - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

William Beumer
Fire Inspector

Ref. # 108336