

Vang, Mai (CI-StPaul)

From: Neis, Adrian (CI-StPaul)
Sent: Thursday, August 01, 2013 2:24 PM
To: maks45@hotmail.com
Cc: Moermond, Marcia (CI-StPaul); Vang, Mai (CI-StPaul); Wiese, Angie (CI-StPaul); Owens, Phil (CI-StPaul); Shaff, Leanna (CI-StPaul)
Subject: 401 Selby Ave.
Attachments: 21564729097.DOC

Good afternoon Malik,

Thank you for meeting me at 401 Selby yesterday.

Based on our inspection, I have advised Vacant Buildings to close their file, and we will handle this under the Fire Certificate of Occupancy. You may remove the red and blue placards from the doors at any time.

This is based on the conditions that the boiler will be repaired or replaced under permit by the heating season, and the water will be turned back on before you allow people to office.

After our conversation, it is my understanding that replacement could begin as early as next week.

Please see the attached correction notice.

I have set up a reinspection for September 4th, 2013.

Please call me once you get this so we can discuss everything in detail.

Thanks,



A.J. Neis
Fire Inspection Supervisor

City of Saint Paul
375 Jackson St. Suite 220
Saint Paul, MN 55101
P: 651-266-8992
F: 651-266-8951
adrian.neis@ci.stpaul.mn.us

The Most Livable
City in America



**Smoke Detectors Save Lives,
Fire Sprinklers Save Lives and Property!**