

☐ Other (Fence Variance, Code Compliance, etc.)

## **APPLICATION FOR APPEAL**

Saint Paul City Council - Legislative Hearings

310 City Hall, 15 W. Kellogg Blvd. Saint Paul, Minnesota 55102 Telephone: (651) 266-8585

Fax: (651) 266-8574

Email: legislativehearings@ci.stpaul.mn.us

## RECEIVED

JUL 17 2014

CITY CLERK	
We need the following to process your appeal:	
\$25 filing fee payable to the City of Saint Paul (if cash: receipt number) Copy of the City-issued orders/letter being appealed Attachments you may wish to include This appeal form completed  Walk-In OR   Mail-In for abatement orders only:   Email OR   Fax	HEARING DATE & TIME (provided by Legislative Hearing Office) Tuesday, July 22, 2014  Time 1:00 a.m. Location of Hearing: Room 330 City Hall/Courthouse
Address Being Appealed:	
Number & Street: 1280 7th street West City:	
Phone Numbers: Business Residence	Date:
Mailing Address if Not Appellant's:	
Phone Numbers: Business Residence	Cell 6/2839 0429
What Is Being Appealed and Why? Attachments Are Acceptable  Vacate Order/Condemnation/ Revocation of Fire C of O  Summary/Vehicle Abatement  Fire C of O Deficiency List  Attachments Are Acceptable  Appealing 3 (as driveny)  Revocation of Fire C of O Deficiency List  Revocation of Cofficiency List  Revocation of Today of the Marshall	
Code Enforcement Correction Notice    Code Enforcement Correction Notice   Code Enforcement Code	
□ Vacant Building Registration Age a	a mint of the dothing



CITY OF SAINT PAUL Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220 Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989 Facsimile: 651-266-8951 Web: <u>www.stpaul.gov/dsi</u>

July 16, 2014

Anton A Soukhanov 1144 Blue Heron Ct St Paul MN 55123-1151

## Revocation of Fire Certificate of Occupancy and Order to Vacate

RE:

1280 7TH ST W

Ref. # 13819

Dear Property Representative:

Your building was inspected on July 16, 2014, for the renewal of the Certificate of Occupancy. Since you have failed to comply with the applicable requirements, it has become necessary to revoke the Certificate of Occupancy in accordance with Section 40.06 of the Saint Paul Legislative Code. A reinspection will be made on August 1, 2014 at 1:00 pm or the property vacated.

The Saint Paul Legislative Code further provides that no building shall be occupied without a Certificate of Occupancy. Failure to immediately complete the following deficiency list or the building vacated may result in a criminal citation.

## **DEFICIENCY LIST**

- 1. Exterior Rear SPLC 34.09 (1) a, 34.32 (1) a Provide and maintain foundation elements to adequately support this building at all points. Top course is crumbling and has holes.
- 2. Exterior Rear SPLC 34.08 (7) All parking spaces shall be paved with asphalt, concrete, or durable dustless surfacing. Before any existing spaces may be paved, site plan approval must be obtained as specified in the St. Paul Zoning Code. Contact DSI Zoning at 651-266-9090.-Per the Legislative Hearing Officer's recommendation: grant until July 15, 2014 for compliance.
- 3. Exterior Rear entry SPLC 34.09 (2) 34.32 (2) Provide an approved guardrail with intermediate ballustrade or rails 4 inches or less apart. This work may require a permit(s). Call DSI at (651) 266-9090.

- 4. Exterior Rear entry SPLC 34.09 (2), 34.32(2) Repair or replace the unsafe stairways, porch, decks or railings in an approved manner. This work may require a permit(s). Call DSI at (651) 266-9090.-Concrete steps are crumbling.
- 5. Front door SPLC 34.09 (3), 34.32 (3) Repair and maintain the door frame.
- 6. Front door Ext. Door SPLC 34.09 (3), 34.33 (3) Repair and maintain the door in good condition.
- 7. Front storm door lock missing Ext. Door SPLC 34.09 (3), 34.33 (3) Repair and maintain the door in good condition.
- 8. Multiple locations SPLC 34.09 (3), 34.33 (3) -Provide or repair and maintain the window screen.
- 9. Unit 1 Front and rear entry doors MSFC 703 Provide, repair or replace the fire rated door and assembly. The minimum rating must be:-Repair the door. Repair and maintain the door closer. Repair and maintain the door latch.
- 10. Unit 1 MN Stat. 299F.362 Immediately provide and maintain a smoke detector located outside each sleeping area.-Found inoperble. Batteries replied and unit tested during inspection. Update 7/16 inspection disabled again, repaired and tested during inspection.
- 11. Unit 2 Bathroom SPLC 34.14 (2) c Provide or replace the duplex convenience outlet with ground fault protection within 3 feet of the basin on an adjacent wall in all bathrooms. This work may require a permit(s). Call DSI at (651) 266-9090.-Broken and will not reset.
- 12. Unit 2 Multiple locations MSFC 605.1 Repair or replace damaged electrical fixtures. This work may require a permit(s). Call DSI at (651) 266-8989.-Outlets are painted over
- 13. Unit 2 Multiple locations SPLC 34.10 (7), 34.34 (6) Repair and maintain the floor in an approved manner.-Repair or replace the carpeting.
- 14. Unit 2 MN Stat. 299F.362 Immediately provide and maintain a smoke detector located outside each sleeping area.-Missing and disabled at time of inspection. Batteries replaced, units tested and reinstalled during inspection. Update 6/17/14: Hallway detector inop. Removed, reinstalled and tested battery during inspection. Update 7/16 inspection same issue, repaired during inspection.
- 15. Unit 3 Bathroom door Ext. Door SPLC 34.09 (3), 34.33 (3) Repair and maintain the door in good condition.-Binds on flooring
- 16. Unit 3 Front and rear door MSFC 703 Provide, repair or replace the fire rated door and assembly.-Repair and maintain the door closer. Repair and maintain the door latch.
- 17. Unit 4 Dining area MSFC 605.1 Repair or replace damaged electrical fixtures. This work may require a permit(s). Call DSI at (651) 266-8989.-Outlet is scorched

- 18. Unit 4 Front and rear entry doors MSFC 703 Provide, repair or replace the fire rated door and assembly.-Repair and maintain the door closer.

  Repair and maintain the door latch.
- 19. Unit 4 Hallway MSFC 605.1 Repair or replace damaged electrical fixtures. This work may require a permit(s). Call DSI at (651) 266-8989.-Cover cracked.
- 20. Unit 4 Kitchen SPLC 34.10 (7), 34.33 (6) Repair and maintain the counter top in an approved manner.
- 21. SPLC 34.09 (1) b,c, 34.33 (1) b, c Provide and maintain all exterior surfaces free from holes and deterioration. All wood exterior unprotected surfaces must be painted or protected from the elements and maintained in a professional manner free from chipped or peeling paint.
- 22. SPLC 39.02(c) Complete and sign the smoke detector affidavit and return it to this office.
- 23. SPLC 34.10 (6), 34.33 (5) Exterminate and control insects, rodents or other pests. Provide documentation of extermination.
- 24. MSFC 1003.3.1.8 Remove unapproved locks from the unit doors. The door must be openable from the inside without the use of keys or special knowledge or effort.-Remove the double cylinder deadbolt from the rear unit door and replace with a single throw deadbolt assembly.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: http://www.stpaul.gov/cofo

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: leanna.shaff@ci.stpaul.mn.us or call me at 651-266-8980 between 7:30 - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Leanna Shaff Fire Inspector

Ref. # 13819