



APPLICATION FOR APPEAL

Saint Paul City Council – Legislative Hearings

RECEIVED

AUG 20 2014

CITY CLERK Email: legislativehearings@ci.stpaul.mn.us

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8585

Fax: (651) 266-8574

We need the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number Check 4870)
 - Copy of the City-issued orders/letter being appealed
 - Attachments you may wish to include
 - This appeal form completed
 - Walk-In OR Mail-In
- for abatement orders only: Email OR Fax

HEARING DATE & TIME (provided by Legislative Hearing Office) Tuesday, <u>8-26-14</u> Time <u>1:30 p.m.</u> Location of Hearing: Room 330 City Hall/Courthouse

e-mailed 8-20-14

Address Being Appealed:

Number & Street: 757 Blair City: ST PAUL State: MN Zip: 55104

Appellant/Applicant: Sally Hoppe Email hopsawm@Q.com

Phone Numbers: Business _____ Residence 651-771-4057 Cell 651-485-4131

Signature: Sally Hoppe Date: 8/19/14

Name of Owner (if other than Appellant): Same

Mailing Address if Not Appellant's: 1616 MONTANA AVE E.

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being Appealed and Why?

Attachments Are Acceptable

- Vacate Order/Condemnation/
- Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other (Fence Variance, Code Compliance, etc.)

need more time - have a contractor & things
are started -
But do not have
a timeline for
completion



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

August 12, 2014

SALLY HOPPE
1616 MONTANA AVE E
ST PAUL MN 55106-1515

FIRE INSPECTION CORRECTION NOTICE

RE: 757 BLAIR AVE

Dear Property Representative:

Your building was inspected on August 8, 2014 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date.

A re-inspection will be made on September 18, 2014 at 10 am.

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

DEFICIENCY LIST

1. House and Garage - SPLC 34.09 (1) b,c, 34.33 (1) b, c - Provide and maintain all exterior walls free from holes and deterioration. All wood exterior unprotected surfaces must be painted or protected from the elements and maintained in a professional manner free from chipped or peeling paint. Paint all peeling areas on the house and garage including all window frames.

2. House and Garage - SPLC 34.09 (1) e, 34.32 (1) d - Provide and maintained the roof weather tight and free from defects. Replace the deteriorated roof on the house and garage.
3. Interior - Throughout - SPLC 34.09 (3), 34.32 (3) - Repair and maintain the window frame.
4. Interior - Basement - MSMC 504.6 - Provide, repair or replace the dryer exhaust duct. Exhaust ducts for domestic clothes dryers shall be constructed of metal and shall have a smooth interior finish. The exhaust duct shall be a minimum nominal size of four inches (102 mm) in diameter and installed in accordance with the mechanical code. This work requires a permit(s). Call DSI at (651) 266-8989.
5. Interior - Basement - SPLC 34.11 (5), 34.34 (2) - Contact a licensed contractor to repair or replace the water heater. This work requires a permit(s). Call DSI at (651) 266-9090.
6. Interior - Basement - MFGC 501.2 - Provide, repair or replace the fuel equipment vent or vent liner to develop a positive flow adequate to convey all products of combustion to the outside. This work requires a permit(s). Call DSI at (651) 266-9090.
7. Interior - Throughout - SPLC 34.09 (3), 34.32 (3) - Repair and maintain the window lock.
8. Interior - Throughout - SPLC 34.10 (7), 34.34 (6) - Repair and maintain the walls in an approved manner. Complete all repairs to the walls in an approved manner.
9. Interior - Throughout - SPLC 34.10 (7), 34.34 (6) - Repair and maintain the ceiling in an approved manner. Complete the repairs to the ceilings in an approved manner.
10. Interior - Throughout - SPLC 34.10 (7), 34.33 (6) - Repair or replace and maintain the woodwork in an approved manner. Repair all door frames and woodwork.
11. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.
12. SPLC 39.02(c) - Complete and sign the smoke detector affidavit and return it to this office.

13. SPLC 34.08(5), 34.32(3) - All accessory structures including, but not limited to, detached garages, sheds and fences shall be maintained structurally sound and in good repair. Provide and maintain exterior unprotected surfaces painted or protected from the elements. Repair the garage in an approved manner. The garage needs to be structurally sound, painted and a new roof. Permits required.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: lisa.martin@ci.stpaul.mn.us or call me at 651-266-8988 between 6:30 a.m. - 8:30 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Lisa Martin
Fire Inspector