



APPLICATION FOR APPEAL

Saint Paul City Council – Legislative Hearings

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8585

RECEIVED

NOV 12 2014

CITY CLERK

We need the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
 - Copy of the City-issued orders/letter being appealed
 - Attachments you may wish to include
 - This appeal form completed
 - Walk-In OR Mail-In
- for abatement orders only: Email OR Fax

HEARING DATE & TIME
(provided by Legislative Hearing Office)
Tuesday, <u>NOV. 18, 2014</u>
Time <u>1:30 P.M.</u>
Location of Hearing:
Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 1707 COTTAGE AVE EAST City: ST. PAUL State: MN Zip: 55106

Appellant/Applicant: JOHN MANN Email: JOHN@JOHNRMANN.COM

Phone Numbers: Business 612-751-1072 Residence _____ Cell _____

Signature: John R. Mann Date: 11-10-14

Name of Owner (if other than Appellant): SAME

Mailing Address if Not Appellant's: SAME 893 DEER OAK RUN
MALDEN, MN 55115

Phone Numbers: Business SAME Residence _____ Cell _____

What Is Being Appealed and Why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other

AWNING WINDOWS - PLEASE GRANDFATHER IN
THANK YOU !!



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

November 5, 2014

JOHN R MANN
893 Deer Oak Run
Mahtomedi MN 55115-2703

FIRE INSPECTION CORRECTION NOTICE

RE: 1707 COTTAGE AVE E
Ref. #102884
Residential Class: C

Dear Property Representative:

Your building was inspected on November 5, 2014 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date. A re-inspection will be made on December 5, 2014 at 1:00P.M.

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

DEFICIENCY LIST

1. All bedrooms - MSFC 1026.1 - Provide and maintain an approved escape window from each sleeping room or area, or discontinue use of area as a sleeping room. This work WILL require permit(s). Call DSI at (651) 266-8989.-Per the owner windows measured . Owner was told could not enforce the egress window code. These are awning windows. 40 inches in width. 25inches in height. The openable height is 14 inches. Openable width is 39inches. The window sill is 56inches and does already have egress steps. The bedroom is 10' by 13.5 feet

2. Remove all gas cans from louse - MN Stat 299F.18 - Immediately remove and discontinue excessive accumulation of combustible materials.
3. Various locations - MSFC 605.5 - Discontinue use of extension cords used in lieu of permanent wiring. usage exceeds amperage.
4. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.
5. SPLC 39.02(c) - Complete and sign the smoke detector affidavit and return it to this office.
6. SPLC 34.08 (7) - All parking spaces shall be paved with asphalt, concrete, or durable dustless surfacing. Before any existing spaces may be paved, site plan approval must be obtained as specified in the St. Paul Zoning Code. Contact DSI Zoning at 651-266-9090.
7. MSMC 504.6 - Provide, repair or replace the dryer exhaust duct. Exhaust ducts for domestic clothes dryers shall be constructed of metal and shall have a smooth interior finish. The exhaust duct shall be a minimum nominal size of four inches (102 mm) in diameter and installed in accordance with the mechanical code. This work will require a permit(s). Call DSI at (651) 266-8989.-The dryer duct does not have code compliant material. The dryer duct at present is split open.
8. MFGC 409.5 - Provide an approved gas shut off valve within 6 feet of the appliance in accordance with the mechanical code. This work may require a permit(s). Call DSI at (651) 266-8989.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: james.thomas@ci.stpaul.mn.us or call me at 651-266-8983 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

James Thomas
Fire Inspector
Reference Number 102884