



**CITY OF SAINT PAUL**  
*Christopher B. Coleman, Mayor*

*375 Jackson Street, Suite 220  
Saint Paul, Minnesota 55101-1806*

*Telephone: 651-266-8989  
Facsimile: 651-266-8951  
Web: [www.stpaul.gov/dsi](http://www.stpaul.gov/dsi)*

March 19, 2015

DANIEL C HEKRDLE  
625 SHOREVIEW CT  
AMERY WI 54001-1547

### **Revocation of Fire Certificate of Occupancy and Order to Vacate**

RE: 670 BELLOWS ST  
Ref. # 122287

Dear Property Representative:

Your building was determined to be a registered vacant building on March 17, 2015. Since certificates are for the occupancy of buildings, it has become necessary to revoke the Certificate of Occupancy.

Saint Paul Legislative Code provides that no building shall be occupied without a Certificate of Occupancy. In order to re-occupy the building, the following deficiencies (if applicable) must be corrected and a complete Certificate of Occupancy inspection will be required.

#### **DEFICIENCY LIST**

1. Interior - Throughout - MSBC -Section 105.1 - Permits Required. Any owner or authorized agent who intends to construct, enlarge, alter, repair, move, demolish, or change the occupancy of a building or structure, or to erect, install, enlarge, alter, repair, remove, convert or replace any electrical, gas, mechanical or plumbing system, the installation of which is regulated by this code, or to cause any such work to be done, shall first make application to the building official and obtain the required permit. Work being done requires a permit. - No permits have been obtained for the recent renovations of home. Due to the scope of the work described by the owner during inspection permits are required for all electrical, mechanical, warm air, and plumbing systems of the home. A building permit is required for the installation of insulation, appropriate vapor barriers and sheet rock.
2. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.

3. SPLC 39.02(c) - Complete and sign the smoke detector affidavit and return it to this office.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: [jeremy.hall@ci.stpaul.mn.us](mailto:jeremy.hall@ci.stpaul.mn.us) or call me at 651-266-8987 between 7:30 - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Jeremy Hall  
Fire Inspector

Ref. # 122287