

## Moermond, Marcia (CI-StPaul)

---

**From:** Migdal, Sebastian (CI-StPaul)  
**Sent:** Wednesday, March 04, 2015 10:12 AM  
**To:** 'Eric Meyer'  
**Subject:** RE: Fire Inspection  
**Attachments:** 20150304100757745.pdf

Hi Eric,

Sorry the appropriate code section is 1008.1.3.4

Please see the attached document and feel free to contact me if you have any questions.

Have a great day!



**Sebastian Migdal**

***Fire Safety Inspector II***

Department of Safety & Inspections

375 Jackson Street, Suite 220

Saint Paul, MN 55102

**P:** 651-266-8985

**F:** 651-266-8951

sebastian.migdal@ci.stpaul.mn.us



Making Saint Paul the Most Livable City in America

---

**From:** Eric Meyer [<mailto:emeyer@cres-inc.com>]  
**Sent:** Tuesday, March 03, 2015 4:37 PM  
**To:** Migdal, Sebastian (CI-StPaul)  
**Subject:** FW: Fire Inspection

Good Afternoon Sebastian:

I've been trying to locate your code reference MSFC 1003.3.1.8. Any chance you can email me a copy of this reference – just having a hard time getting my hands on this reference. This is regarding the elevator lobby's at the Golden Rule Building.

Our team is working on the other items. I know my boss will be asking me many questions regarding the elevator lobby's, so I appreciate the help.

Thanks,

Eric Meyer

Operations Manager

Commercial Real Estate Services, Inc.

85 East Seventh Place Suite 200

St. Paul, MN 55101

Phone 612.790.9058

Fax 651.224.4048



---

**From:** Migdal, Sebastian (CI-StPaul) [<mailto:sebastian.migdal@ci.stpaul.mn.us>]

**Sent:** Wednesday, February 25, 2015 5:03 PM

**To:** Eric Meyer

**Subject:** Fire Inspection

Hello Eric,

Thank you for being patient with me. Good news! Looks like that card reader can stay in the DHS space, but the exit sign will have to be removed. Please take a peek at the orders and let me know if you have any questions/concerns.

Thanks.



**Sebastian Migdal**

***Fire Safety Inspector II***

Department of Safety & Inspections

375 Jackson Street, Suite 220

Saint Paul, MN 55102

**P:** 651-266-8985

**F:** 651-266-8951

[sebastian.migdal@ci.stpaul.mn.us](mailto:sebastian.migdal@ci.stpaul.mn.us)

The Most Livable  
City in America



Making Saint Paul the Most Livable City in America