



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street., Suite 220
Saint Paul, MN 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-1919
Web: www.stpaul.gov/dsi

- Yog hais tias koj hais tsis to taub tsab ntawv no, hu rau tus txhais lus ntawm (651) 266-8989. Nws yog pab dawb zwb.
- Si necessita un traductor, por favor llamanos al (651)266-8989. No costo.

364

October 09, 2015

Gerardo L Gonzalez/Carolina Ybarra
906 Russell St
St Paul MN 55106-3822

CORRECTION NOTICE

RE: **906 RUSSELL ST**
File #: **15-162521**

Dear Sir or Madam:

The City of Saint Paul, Department of Safety and Inspections has inspected the above referenced property on **October 09, 2015** and has determined that the following deficiencies exist in violation of the Saint Paul Legislative Code¹ (see footnote 1, below).

- 1. Lack of Electricity. Immediately restore electrical service. Failure to provide proper electrical service will result in these premises being declared Unfit for Human Habitation and ordered vacated for lack of this basic facility. Use of candles, fuel operated lighting or extension cord wiring is not permitted while the power is off. REMOVE EXTENSION CORD TO THE NEIGHBORS PROPERTY IMMEDIATELY.**
2. Smoke Detector: Lack of properly installed and operable smoke detector. Provide functioning smoke detectors in accordance with the attached requirement, within 24 hours. NEEDS BATTERY
3. Remove illegal lock on the bedroom door.
4. MN State Statute 299F.50 Immediately provide and maintain an approved carbon monoxide alarm in a location within ten (10) feet of each sleeping area. Installation shall be in accordance with manufacturers instructions.
5. There is an excessive amount on soiled clothing in the basement and around the furnace. Remove
6. Remove gas can under bathroom sink
7. Install missing cover plate in the Kitchen.
8. STORM DOOR(S): The storm door(s) are in disrepair; repair or replace the door(s).

9. The window and/or door screens are missing, defective or in a state of disrepair. Provide proper window and door screens for all openable windows and doors. Screens must be tight-fitting and securely fastened to the frames.
10. Repair the steps off the deck

You are hereby notified to correct these deficiencies in accordance with the appropriate codes. The Enforcement Officer will reinspect these premises on or after **October 14, 2015**, by which date the violations noted must be corrected. **Failure to correct these deficiencies may result in the issuance of criminal charges²** and/or a civil lawsuit, and possible abatement/assessment by the City. All repairs and new installations must be made in accordance with the appropriate codes. Permits may be obtained by calling 651-266-8989.

You may file an appeal to this notice by contacting the City Clerk at 651-266-8585. Any appeal must be made in writing within 10 days of this notice. (You must submit a copy of this Notice when you appeal, and pay a filing fee.)

If you have any questions or request additional information, please contact me. To arrange an appointment or request an extension of time to complete repairs, you will need to speak directly to me at 651-266-1916.

Sincerely,

Paula Seeley
Badge # 364

CODE ENFORCEMENT OFFICER

Footnotes:

¹ To see the Legislative Code go to www.stpaul.gov on the internet, click on "Departments", then click on "Department of Safety and Inspections", scroll down the page for the "Codes". Most Correction Notices derive from Chapter 34.

² Criminal charges can be brought on the day the violation is observed, but generally we allow time to correct unless this is a repeat violation.

ps

WARNING Code inspection and enforcement trips cost the taxpayers money. If the violations are not corrected within the time period required in this notice, the city's costs in conducting a reinspection after the due date for compliance will be collected from the owner rather than being paid by the taxpayers of the city. If additional new violations are discovered within the next following 12 months, the city's costs in conducting additional inspections at this same location within such 12 months will be collected from the owner rather than being paid by the taxpayers of the city. Any such future costs will be collected by assessment against the real property and are in addition to any other fines or assessments which may be levied against you and your property.