



# APPLICATION FOR APPEAL

## Saint Paul City Council – Legislative Hearings

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8585

RECEIVED

DEC 21 2015

CITY CLERK

We need the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number check # 5913)
  - Copy of the City-issued orders/letter being appealed
  - Attachments you may wish to include
  - This appeal form completed
  - Walk-In OR  Mail-In
- for abatement orders only:  Email OR  Fax

<b>HEARING DATE &amp; TIME</b> (provided by Legislative Hearing Office) Tuesday, <u>January 5<sup>th</sup> 2016</u>
Time: <u>11:00 p.m.</u>
<b>Location of Hearing:</b> Room 330 City Hall/Courthouse

### Address Being Appealed:

Number & Street: 1335 BEECHWOOD PL City: ST. PAUL State: MN Zip: 55116

Appellant/Applicant: JOHN & LEE MANNILLO Email: JOHN@MANNILLOWOMACK.COM  
651 651 651

Phone Numbers: Business 292-8306 Residence 699-3322 Cell 592-4525

Signature: [Handwritten Signature] Date: 12/21/15

Name of Owner (if other than Appellant): N/A

Mailing Address if Not Appellant's: N/A

Phone Numbers: Business \_\_\_\_\_ Residence \_\_\_\_\_ Cell \_\_\_\_\_

### What Is Being Appealed and Why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other

Fence enclosing pool area must be no less than 4' in height. THIS RELATES TO THE BEECHWOOD PL. SIDE OF HOUSE.



CITY OF SAINT PAUL  
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220  
Saint Paul, MN 55101-1806

Telephone: 651-266-8989  
Facsimile: 651-266-1919  
Web: [www.stpaul.gov/dsi](http://www.stpaul.gov/dsi)

- Yog hais tias koj hais tsis to taub tsab ntawv no, hu rau tus txhais lus ntawm (651) 266-8989. Nws yog pab dawb zwb.
- Si necessita un traductor, por favor llamanos al (651)266-8989. No costo.

334

**December 16, 2015**

John E Mannillo/Lee A Mannillo  
1335 Beechwood Pl  
St Paul MN 55116-2202

## CORRECTION NOTICE

RE: **1335 BEECHWOOD PLACE**  
File #: **15-185851**

Dear Sir or Madam:

The City of Saint Paul, Department of Safety and Inspections has inspected the above referenced property on **December 16, 2015** and has determined that the following deficiencies exist in violation of the Saint Paul Legislative Code<sup>1</sup> (see footnote 1, below).

1. FENCE ENCLOSING POOL AREA MUST BE NO LESS THAN 4 FEET IN HEIGHT. FENCE ON BEECHWOOD PLACE SIDE OF HOUSE DOES NOT MEET THIS REQUIREMENT.

You are hereby notified to correct these deficiencies in accordance with the appropriate codes. The Enforcement Officer will reinspect these premises on or after **March 17, 2016**, by which date the violations noted must be corrected. **Failure to correct these deficiencies may result in the issuance of criminal charges<sup>2</sup>** and/or a civil lawsuit, and possible abatement/assessment by the City. All repairs and new installations must be made in accordance with the appropriate codes. Permits may be obtained by calling 651-266-8989.

You may file an appeal to this notice by contacting the City Clerk at 651-266-8585. Any appeal must be made in writing within 10 days of this notice. (You must submit a copy of this Notice when you appeal, and pay a filing fee.)

**If you have any questions or request additional information, please contact me. To arrange an appointment or request an extension of time to complete repairs, you will need to speak directly to me at 651-266-1908.**

Sincerely,

**Mark Kaisersatt**  
Badge # 334

**CODE ENFORCEMENT OFFICER**

Footnotes:

- <sup>1</sup> To see the Legislative Code go to [www.stpaul.gov](http://www.stpaul.gov) on the internet, click on "Departments", then click on "Department of Safety and Inspections", scroll down the page for the "Codes". Most Correction Notices derive from Chapter 34.
- <sup>2</sup> Criminal charges can be brought on the day the violation is observed, but generally we allow time to correct unless this is a repeat violation.

mk

**WARNING** Code inspection and enforcement trips cost the taxpayers money. If the violations are not corrected within the time period required in this notice, the city's costs in conducting a reinspection after the due date for compliance will be collected from the owner rather than being paid by the taxpayers of the city. If additional new violations are discovered within the next following 12 months, the city's costs in conducting additional inspections at this same location within such 12 months will be collected from the owner rather than being paid by the taxpayers of the city. Any such future costs will be collected by assessment against the real property and are in addition to any other fines or assessments which may be levied against you and your property.

cn60100 4/13