



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

*375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806*

*Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi*

January 26, 2016

Tim Hanson
740 Stewart Ave Unit 2
Saint Paul MN 55102-4119

Revocation of Fire Certificate of Occupancy and Order to Vacate

RE: 740 STEWART AVE
Ref. # 16272

Dear Property Representative:

Your building was inspected on January 21, 2016, for the renewal of the Certificate of Occupancy. Since you have failed to comply with the applicable requirements, it has become necessary to revoke the Certificate of Occupancy in accordance with Section 40.06 of the Saint Paul Legislative Code. A reinspection will be made on a future date set by the Legislative Hearing Officer or the property vacated.

The Saint Paul Legislative Code further provides that no building shall be occupied without a Certificate of Occupancy. Failure to immediately complete the following deficiency list or the building vacated may result in a criminal citation.

DEFICIENCY LIST

1. Exterior - Rear - SPLC 65.141 (g) There shall be no exterior storage of equipment, supplies or commercial vehicles associated with the home occupation, nor parking of more than one (1) business car, pickup truck or small van, nor any additional vehicles except those for permitted employees identified under paragraph (d).
-Remove all business equipment including wood pallets, pump jacks, siding materials, ladders, planks and stored rain gutters.
2. Exterior - Rear - SPLC 34.08 (6), 34.31 (4) - Remove the accumulation of exterior storage that creates a nuisance or harbors rodents.-Remove all pallets, construction material and work equipment from the property.
3. Rear - SPLC 34.08 (7) - All parking spaces shall be paved with asphalt, concrete, or durable dustless surfacing. Before any existing spaces may be paved, site plan approval must be obtained as specified in the St. Paul Zoning Code. Contact DSI Zoning at 651-266-8989.

4. Unit 4 - MSFC 703 - Provide, repair or replace the fire rated door and assembly. -Repair and maintain the door closer.
5. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.
6. MSFC 304.3.3 - Relocate dumpster at least 5 feet away from combustible walls, openings, or combustible eaves and overhangs.
7. MSFC 901.6 - Provide required annual maintenance of the fire extinguishers by a qualified person and tag the fire extinguishers with the date of service.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: Justin.Elvestad@ci.stpaul.mn.us or call me at 651-266-8982 between 7:30 - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Justin Elvestad
Fire Inspector

Ref. # 16272