



CITY OF SAINT PAUL
Department of Safety & Inspections
Fire Safety Inspection Division

HEATING SYSTEM TEST REPORT

(Use a separate form for each appliance)

375 Jackson Street Suite 220
 Saint Paul, MN 55101-1806
 (P) 651-266-8989 (F) 651-266-8951

Revised 07/2014

Fire Inspector/Email _____ @ci.stpaul.mn.us

ADDRESS: 287 Page St. E.

OWNER: Bill Berger

DATE: 2/8/16

Type of Heat:

- Gravity Air Forced Air Gravity Hot Water Forced Hot Water
 Steam Unit Heater Space Heater Other:

Type of Fuel: Gas Oil Other:

Gas Design

Make of Burner: Lennox
 Model: G20034E-100-3
 Serial: 5893G05909
 Input: 100,000 btu

Conversion

Make:
 Model:
 Max BTU Rating:
 Make of Furnace:

Equipment Venting Type: Atmospheric Induced Fan Other:

Total BTU input of all vented gas appliances per chimney:

- Type of Chimney: Masonry Class B Other: 132,000 btu
 Type of Liner: None Metal Clay Tile
 Vent Connector Material: Type-C Type-B
 Combustion Air Supply Required? Yes No Installed? Yes No

Safety & Operating Control Tests:

- Pilot/Flame Safeguard Operating Properly
 Limit(s) Operating Properly
 Operator(s) Operating Properly
 Low Water Cut-off Operating Properly
 All Controls Operating Properly

Yes	No
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>

Fuel Analysis/Flue Gas Analysis:

- Vents properly without spillage
 Flame stays inside/Doesn't roll out
 Burner lights smoothly

Yes	No
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>

Combustion Analysis			Visual Inspection	
Stack Temperature	<u>353</u>	°F/Net	Fuel Piping System – Okay?	<input checked="" type="checkbox"/>
Oxygen	<u>6.0</u>	%	Vent Systems: Draft hood, Connector, Vent Chimney – Okay?	<input checked="" type="checkbox"/>
Carbon Dioxide	<u>8.5</u>	%	Heating Unit – Okay?	<input checked="" type="checkbox"/>
Carbon Monoxide	<u>37</u>	PPM		

Look At The Total Heating System Before You Leave:

Yes	No
<input checked="" type="checkbox"/>	<input type="checkbox"/>

COMMENTS:

Name of Licensed Contractor	Forrest Heating, Inc.	Address	995 Burns Ave. St. Paul, MN 55106	Phone	651-776-4585
Person Doing the Test (Print):	Charles Forrest	Signature:			
Certificate of Competency from the City of Saint Paul for Appropriate Fuel:			0428		

THIS TEST IS VALID FOR ONE (1) YEAR