



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

*375 Jackson Street, Suite 220
St Paul, Minnesota 55101-1806*

*Telephone: 651-266-8989
Facsimile: 651-266-9124
Web: www.stpaul.gov/dsi*

September 17, 2015

Re: Site Review
Code Compliance Team Inspection (Building)

Address: 719 Payne Ave.

Deficiencies

Inside:

- 1) Properly install ceiling grid system for dropped ceiling. SPLC Sect. 34.34 (6)
- 2) Insure emergency pump shut off switch in proper location.

Outside:

- 1) Insure fuel tanks certified.
- 2) Install new roof covering and insure roof insulated to code. SPLC Sect. 34.33 (1) d
- 3) Insure accessible parking is marked and located to code. MSDC Sect. 1106/

James Seeger
Code Compliance Officer